




BACnet DPL

 Data points that need to be set are marked in green

 System specific data points which are frequently set are marked in blue

 More possible system specific data points are marked in white

V003 - 10/2014

	mandatory	mandatory	mandatory	mandatory	mandatory	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional
	#keyname	device obj.-instance	object-name	object-type	object-instance	description	present-value-default	min-present-value	max-present-value	settable	supports COV	hi-limit	low-limit	state-text-reference	unit-code	vendor-specific-address
system data	Device (BACnet Device Object)	200	TROX_856581	8	200	only for information				N	Y					
	CurrentConfig.xml (BACnet File Object)	200	CurrentConfig.xml	10	0	only for information				N	Y					
	BACnetOnline_1010010.wbp (BACnet File Object)	200	BACnetOnline_1010010.wbp	10	1	only for information				N	Y					
	IO (BACnet Structured View Object)	200	IO	29	0	only for information				N	Y					
	bInHeartBeat2PLC (BACnet Binary Output Object)	200	bInHeartBeat2PLC	4	1	Heart beat from BMS to the local PLC	inactive			Y	Y			1		
	bInResetErrors (BACnet Binary Output Object)	200	bInResetErrors	4	2	reset all errors	inactive			Y	Y			1		
	bInLight (BACnet Binary Output Object)	200	bInLight	4	3	Switch on/off	inactive			Y	Y			1		
	bInTestFireDampers (BACnet Binary Output Object)	200	bInTestFireDampers	4	4	starts test of all fire dampers	inactive			Y	Y			1		
	eInSystemMode (BACnet Analog Output Object)	200	eInSystemMode	1	5	set the units operation mode [0=units off,1=manual mode, 2 = auto]	0	0	2	Y	Y	2	0		95	
	fInMeasTempOutdoor (BACnet Analog Output Object)	200	fInMeasTempOutdoor	1	6	present value outdoor temperature true = set the unit in stand by, false = unit will run in auto if eInSystemMode =2 and there is no critical error	0	-3,40E+38	3,40E+38	Y	Y	3,40E+38	-3,40E+38		62	
system data	bInSPStandby (BACnet Binary Output Object)	200	bInSPStandby	4	7		inactive			Y	Y			1		
	fInSPFanSUP (BACnet Analog Output Object)	200	fInSPFanSUP	1	8	setpoint of the supply air fan	0	-3,40E+38	3,40E+38	Y	Y	3,40E+38	-3,40E+38		95	
	fInSPFanETA (BACnet Analog Output Object)	200	fInSPFanETA	1	9	setpoint of the extract air fan	0	-3,40E+38	3,40E+38	Y	Y	3,40E+38	-3,40E+38		95	
	fInSPTempMin (BACnet Analog Output Object)	200	fInSPTempMin	1	10	setpoint of the minimal air temperature	0	-3,40E+38	3,40E+38	Y	Y	3,40E+38	-3,40E+38		62	
	fInSPTempMax (BACnet Analog Output Object)	200	fInSPTempMax	1	11	setpoint of the maximal air temperature	0	-3,40E+38	3,40E+38	Y	Y	3,40E+38	-3,40E+38		62	
	fInSPHumMin (BACnet Analog Output Object)	200	fInSPHumMin	1	12	setpoint of the minimal air humidity	0	-3,40E+38	3,40E+38	Y	Y	3,40E+38	-3,40E+38		28	
	fInSPHumMax (BACnet Analog Output Object)	200	fInSPHumMax	1	13	setpoint of the maximal air humidity	0	-3,40E+38	3,40E+38	Y	Y	3,40E+38	-3,40E+38		28	
	fInSPTempSUPMin (BACnet Analog Output Object)	200	fInSPTempSUPMin	1	14	setpoint of the minimal supply air temperature	0	-3,40E+38	3,40E+38	Y	Y	3,40E+38	-3,40E+38		62	
	fInSPTempSUPMax (BACnet Analog Output Object)	200	fInSPTempSUPMax	1	15	setpoint of the maximal supply air temperature	0	-3,40E+38	3,40E+38	Y	Y	3,40E+38	-3,40E+38		62	
	fInSPHumSUPMin (BACnet Analog Output Object)	200	fInSPHumSUPMin	1	16	setpoint of the minimal supply air humidity	0	-3,40E+38	3,40E+38	Y	Y	3,40E+38	-3,40E+38		28	
system data	fInSPHumSUPMax (BACnet Analog Output Object)	200	fInSPHumSUPMax	1	17	setpoint of the maximal supply air humidity	0	-3,40E+38	3,40E+38	Y	Y	3,40E+38	-3,40E+38		28	
	bOutHeartbeat2BMS (BACnet Binary Input Object)	200	bOutHeartbeat2BMS	3	0	heart beat from to local plc to the BMS				N	Y			1		
	bOutLight (BACnet Binary Input Object)	200	bOutLight	3	1	true if the light is on otherwise false				N	Y			1		
	bOutExtLock (BACnet Binary Input Object)	200	bOutExtLock	3	2	false if the unit have been lock over an external signal otherwise true				N	Y			1		

	mandatory	mandatory	mandatory	mandatory	mandatory	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional
	#keyname	device obj.-instance	object-name	object-type	object-instance	description	present-value-default	min-present-value	max-present-value	settable	supports COV	hi-limit	low-limit	state-text-reference	unit-code	vendor-specific-address
state of extern alarm	bOutExtAlarm1 (BACnet Binary Input Object)	200	bOutExtAlarm1	3	3	State of the extern alarm number 1				N	Y			1		
	bOutExtAlarm2 (BACnet Binary Input Object)	200	bOutExtAlarm2	3	4	State of the extern alarm number 2				N	Y			1		
	bOutExtAlarm3 (BACnet Binary Input Object)	200	bOutExtAlarm3	3	5	State of the extern alarm number 3				N	Y			1		
	bOutExtAlarm4 (BACnet Binary Input Object)	200	bOutExtAlarm4	3	6	State of the extern alarm number 4				N	Y			1		
	bOutExtAlarm5 (BACnet Binary Input Object)	200	bOutExtAlarm5	3	7	State of the extern alarm number 5				N	Y			1		
	bOutExtAlarm6 (BACnet Binary Input Object)	200	bOutExtAlarm6	3	8	State of the extern alarm number 6				N	Y			1		
	bOutExtAlarm7 (BACnet Binary Input Object)	200	bOutExtAlarm7	3	9	State of the extern alarm number 7				N	Y			1		
	bOutExtAlarm8 (BACnet Binary Input Object)	200	bOutExtAlarm8	3	10	State of the extern alarm number 8				N	Y			1		
	bOutExtAlarm9 (BACnet Binary Input Object)	200	bOutExtAlarm9	3	11	State of the extern alarm number 9				N	Y			1		
	bOutExtAlarm10 (BACnet Binary Input Object)	200	bOutExtAlarm10	3	12	State of the extern alarm number 10				N	Y			1		
fire damper	bOutFireDamperClosed1 (BACnet Binary Input Object)	200	bOutFireDamperClosed1	3	13	contact fire damper 1 closed				N	Y			1		
	bOutFireDamperClosed2 (BACnet Binary Input Object)	200	bOutFireDamperClosed2	3	14	contact fire damper 2 closed				N	Y			1		
	bOutFireDamperClosed3 (BACnet Binary Input Object)	200	bOutFireDamperClosed3	3	15	contact fire damper 3 closed				N	Y			1		
	bOutFireDamperClosed4 (BACnet Binary Input Object)	200	bOutFireDamperClosed4	3	16	contact fire damper 4 closed				N	Y			1		
	bOutFireDamperClosed5 (BACnet Binary Input Object)	200	bOutFireDamperClosed5	3	17	contact fire damper 5 closed				N	Y			1		
	bOutFireDamperClosed6 (BACnet Binary Input Object)	200	bOutFireDamperClosed6	3	18	contact fire damper 6 closed				N	Y			1		
	bOutFireDamperClosed7 (BACnet Binary Input Object)	200	bOutFireDamperClosed7	3	19	contact fire damper 7 closed				N	Y			1		
	bOutFireDamperClosed8 (BACnet Binary Input Object)	200	bOutFireDamperClosed8	3	20	contact fire damper 8 closed				N	Y			1		
	bOutFireDamperClosed9 (BACnet Binary Input Object)	200	bOutFireDamperClosed9	3	21	contact fire damper 9 closed				N	Y			1		
	bOutFireDamperClosed10 (BACnet Binary Input Object)	200	bOutFireDamperClosed10	3	22	contact fire damper 10 closed				N	Y			1		
	bOutFireDamperClosed11 (BACnet Binary Input Object)	200	bOutFireDamperClosed11	3	23	contact fire damper 11 closed				N	Y			1		
	bOutFireDamperClosed12 (BACnet Binary Input Object)	200	bOutFireDamperClosed12	3	24	contact fire damper 12 closed				N	Y			1		
	bOutFireDamperClosed13 (BACnet Binary Input Object)	200	bOutFireDamperClosed13	3	25	contact fire damper 13 closed				N	Y			1		
	bOutFireDamperClosed14 (BACnet Binary Input Object)	200	bOutFireDamperClosed14	3	26	contact fire damper 14 closed				N	Y			1		
	bOutFireDamperClosed15 (BACnet Binary Input Object)	200	bOutFireDamperClosed15	3	27	contact fire damper 15 closed				N	Y			1		
	bOutFireDamperClosed16 (BACnet Binary Input Object)	200	bOutFireDamperClosed16	3	28	contact fire damper 16 closed				N	Y			1		
	bOutFireDamperClosed17 (BACnet Binary Input Object)	200	bOutFireDamperClosed17	3	29	contact fire damper 17 closed				N	Y			1		
	bOutFireDamperClosed18 (BACnet Binary Input Object)	200	bOutFireDamperClosed18	3	30	contact fire damper 18 closed				N	Y			1		
	bOutFireDamperClosed19 (BACnet Binary Input Object)	200	bOutFireDamperClosed19	3	31	contact fire damper 19 closed				N	Y			1		
	bOutFireDamperClosed20 (BACnet Binary Input Object)	200	bOutFireDamperClosed20	3	32	contact fire damper 20 closed				N	Y			1		
	bOutFireDamperClosed21 (BACnet Binary Input Object)	200	bOutFireDamperClosed21	3	33	contact fire damper 21 closed				N	Y			1		
	bOutFireDamperClosed22 (BACnet Binary Input Object)	200	bOutFireDamperClosed22	3	34	contact fire damper 22 closed				N	Y			1		
	bOutFireDamperClosed23 (BACnet Binary Input Object)	200	bOutFireDamperClosed23	3	35	contact fire damper 23 closed				N	Y			1		
	bOutFireDamperClosed24 (BACnet Binary Input Object)	200	bOutFireDamperClosed24	3	36	contact fire damper 24 closed				N	Y			1		
	bOutFireDamperClosed25 (BACnet Binary Input Object)	200	bOutFireDamperClosed25	3	37	contact fire damper 25 closed				N	Y			1		

	mandatory	mandatory	mandatory	mandatory	mandatory	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional
	#keyname	device obj.-instance	object-name	object-type	object-instance	description	present-value-default	min-present-value	max-present-value	settable	supports COV	hi-limit	low-limit	state-text-reference	unit-code	vendor-specific-address
fire damper	bOutFireDamperClosed26 (BACnet Binary Input Object)	200	bOutFireDamperClosed26	3	38	contact fire damper 26 closed				N	Y			1		
	bOutFireDamperClosed27 (BACnet Binary Input Object)	200	bOutFireDamperClosed27	3	39	contact fire damper 27 closed				N	Y			1		
	bOutFireDamperClosed28 (BACnet Binary Input Object)	200	bOutFireDamperClosed28	3	40	contact fire damper 28 closed				N	Y			1		
	bOutFireDamperClosed29 (BACnet Binary Input Object)	200	bOutFireDamperClosed29	3	41	contact fire damper 29 closed				N	Y			1		
	bOutFireDamperClosed30 (BACnet Binary Input Object)	200	bOutFireDamperClosed30	3	42	contact fire damper 30 closed				N	Y			1		
	bOutFireDamperClosed31 (BACnet Binary Input Object)	200	bOutFireDamperClosed31	3	43	contact fire damper 31 closed				N	Y			1		
	bOutFireDamperClosed32 (BACnet Binary Input Object)	200	bOutFireDamperClosed32	3	44	contact fire damper 32 closed				N	Y			1		
	bOutFireDamperClosed33 (BACnet Binary Input Object)	200	bOutFireDamperClosed33	3	45	contact fire damper 33 closed				N	Y			1		
	bOutFireDamperClosed34 (BACnet Binary Input Object)	200	bOutFireDamperClosed34	3	46	contact fire damper 34 closed				N	Y			1		
	bOutFireDamperClosed35 (BACnet Binary Input Object)	200	bOutFireDamperClosed35	3	47	contact fire damper 35 closed				N	Y			1		
	bOutFireDamperClosed36 (BACnet Binary Input Object)	200	bOutFireDamperClosed36	3	48	contact fire damper 36 closed				N	Y			1		
	bOutFireDamperClosed37 (BACnet Binary Input Object)	200	bOutFireDamperClosed37	3	49	contact fire damper 37 closed				N	Y			1		
	bOutFireDamperClosed38 (BACnet Binary Input Object)	200	bOutFireDamperClosed38	3	50	contact fire damper 38 closed				N	Y			1		
	bOutFireDamperClosed39 (BACnet Binary Input Object)	200	bOutFireDamperClosed39	3	51	contact fire damper 39 closed				N	Y			1		
	bOutFireDamperClosed40 (BACnet Binary Input Object)	200	bOutFireDamperClosed40	3	52	contact fire damper 40 closed				N	Y			1		
	bOutFireDamperClosed41 (BACnet Binary Input Object)	200	bOutFireDamperClosed41	3	53	contact fire damper 41 closed				N	Y			1		
	bOutFireDamperClosed42 (BACnet Binary Input Object)	200	bOutFireDamperClosed42	3	54	contact fire damper 42 closed				N	Y			1		
	bOutFireDamperClosed43 (BACnet Binary Input Object)	200	bOutFireDamperClosed43	3	55	contact fire damper 43 closed				N	Y			1		
	bOutFireDamperClosed44 (BACnet Binary Input Object)	200	bOutFireDamperClosed44	3	56	contact fire damper 44 closed				N	Y			1		
	bOutFireDamperClosed45 (BACnet Binary Input Object)	200	bOutFireDamperClosed45	3	57	contact fire damper 45 closed				N	Y			1		
	bOutFireDamperClosed46 (BACnet Binary Input Object)	200	bOutFireDamperClosed46	3	58	contact fire damper 46 closed				N	Y			1		
	bOutFireDamperClosed47 (BACnet Binary Input Object)	200	bOutFireDamperClosed47	3	59	contact fire damper 47 closed				N	Y			1		
	bOutFireDamperClosed48 (BACnet Binary Input Object)	200	bOutFireDamperClosed48	3	60	contact fire damper 48 closed				N	Y			1		
	bOutFireDamperClosed49 (BACnet Binary Input Object)	200	bOutFireDamperClosed49	3	61	contact fire damper 49 closed				N	Y			1		
	bOutFireDamperClosed50 (BACnet Binary Input Object)	200	bOutFireDamperClosed50	3	62	contact fire damper 50 closed				N	Y			1		
	bOutFireDamperClosed51 (BACnet Binary Input Object)	200	bOutFireDamperClosed51	3	63	contact fire damper 51 closed				N	Y			1		
	bOutFireDamperClosed52 (BACnet Binary Input Object)	200	bOutFireDamperClosed52	3	64	contact fire damper 52 closed				N	Y			1		
	bOutFireDamperClosed53 (BACnet Binary Input Object)	200	bOutFireDamperClosed53	3	65	contact fire damper 53 closed				N	Y			1		
	bOutFireDamperClosed54 (BACnet Binary Input Object)	200	bOutFireDamperClosed54	3	66	contact fire damper 54 closed				N	Y			1		
	bOutFireDamperClosed55 (BACnet Binary Input Object)	200	bOutFireDamperClosed55	3	67	contact fire damper 55 closed				N	Y			1		
bOutFireDamperClosed56 (BACnet Binary Input Object)	200	bOutFireDamperClosed56	3	68	contact fire damper 56 closed				N	Y			1			
bOutFireDamperClosed57 (BACnet Binary Input Object)	200	bOutFireDamperClosed57	3	69	contact fire damper 57 closed				N	Y			1			
bOutFireDamperClosed58 (BACnet Binary Input Object)	200	bOutFireDamperClosed58	3	70	contact fire damper 58 closed				N	Y			1			
bOutFireDamperClosed59 (BACnet Binary Input Object)	200	bOutFireDamperClosed59	3	71	contact fire damper 59 closed				N	Y			1			
bOutFireDamperClosed60 (BACnet Binary Input Object)	200	bOutFireDamperClosed60	3	72	contact fire damper 60 closed				N	Y			1			

	mandatory	mandatory	mandatory	mandatory	mandatory	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional	
	#keyname	device obj.-instance	object-name	object-type	object-instance	description	present-value-default	min-present-value	max-present-value	settable	supports COV	hi-limit	low-limit	state-text-reference	unit-code	vendor-specific-address	
fire damper	bOutFireDamperClosed61 (BACnet Binary Input Object)	200	bOutFireDamperClosed61	3	73	contact fire damper 61 closed				N	Y			1			
	bOutFireDamperClosed62 (BACnet Binary Input Object)	200	bOutFireDamperClosed62	3	74	contact fire damper 62 closed				N	Y			1			
	bOutFireDamperOpened1 (BACnet Binary Input Object)	200	bOutFireDamperOpened1	3	75	contact fire damper 1 Opened				N	Y			1			
	bOutFireDamperOpened2 (BACnet Binary Input Object)	200	bOutFireDamperOpened2	3	76	contact fire damper 2 Opened				N	Y			1			
	bOutFireDamperOpened3 (BACnet Binary Input Object)	200	bOutFireDamperOpened3	3	77	contact fire damper 3 Opened				N	Y			1			
	bOutFireDamperOpened4 (BACnet Binary Input Object)	200	bOutFireDamperOpened4	3	78	contact fire damper 4 Opened				N	Y			1			
	bOutFireDamperOpened5 (BACnet Binary Input Object)	200	bOutFireDamperOpened5	3	79	contact fire damper 5 Opened				N	Y			1			
	bOutFireDamperOpened6 (BACnet Binary Input Object)	200	bOutFireDamperOpened6	3	80	contact fire damper 6 Opened				N	Y			1			
	bOutFireDamperOpened7 (BACnet Binary Input Object)	200	bOutFireDamperOpened7	3	81	contact fire damper 7 Opened				N	Y			1			
	bOutFireDamperOpened8 (BACnet Binary Input Object)	200	bOutFireDamperOpened8	3	82	contact fire damper 8 Opened				N	Y			1			
	bOutFireDamperOpened9 (BACnet Binary Input Object)	200	bOutFireDamperOpened9	3	83	contact fire damper 9 Opened				N	Y			1			
	bOutFireDamperOpened10 (BACnet Binary Input Object)	200	bOutFireDamperOpened10	3	84	contact fire damper 10 Opened				N	Y			1			
	bOutFireDamperOpened11 (BACnet Binary Input Object)	200	bOutFireDamperOpened11	3	85	contact fire damper 11 Opened				N	Y			1			
	bOutFireDamperOpened12 (BACnet Binary Input Object)	200	bOutFireDamperOpened12	3	86	contact fire damper 12 Opened				N	Y			1			
	bOutFireDamperOpened13 (BACnet Binary Input Object)	200	bOutFireDamperOpened13	3	87	contact fire damper 13 Opened				N	Y			1			
	bOutFireDamperOpened14 (BACnet Binary Input Object)	200	bOutFireDamperOpened14	3	88	contact fire damper 14 Opened				N	Y			1			
	fire damper	bOutFireDamperOpened15 (BACnet Binary Input Object)	200	bOutFireDamperOpened15	3	89	contact fire damper 15 Opened				N	Y			1		
		bOutFireDamperOpened16 (BACnet Binary Input Object)	200	bOutFireDamperOpened16	3	90	contact fire damper 16 Opened				N	Y			1		
bOutFireDamperOpened17 (BACnet Binary Input Object)		200	bOutFireDamperOpened17	3	91	contact fire damper 17 Opened				N	Y			1			
bOutFireDamperOpened18 (BACnet Binary Input Object)		200	bOutFireDamperOpened18	3	92	contact fire damper 18 Opened				N	Y			1			
bOutFireDamperOpened19 (BACnet Binary Input Object)		200	bOutFireDamperOpened19	3	93	contact fire damper 19 Opened				N	Y			1			
bOutFireDamperOpened20 (BACnet Binary Input Object)		200	bOutFireDamperOpened20	3	94	contact fire damper 20 Opened				N	Y			1			
bOutFireDamperOpened21 (BACnet Binary Input Object)		200	bOutFireDamperOpened21	3	95	contact fire damper 21 Opened				N	Y			1			
bOutFireDamperOpened22 (BACnet Binary Input Object)		200	bOutFireDamperOpened22	3	96	contact fire damper 22 Opened				N	Y			1			
bOutFireDamperOpened23 (BACnet Binary Input Object)		200	bOutFireDamperOpened23	3	97	contact fire damper 23 Opened				N	Y			1			
bOutFireDamperOpened24 (BACnet Binary Input Object)		200	bOutFireDamperOpened24	3	98	contact fire damper 24 Opened				N	Y			1			
bOutFireDamperOpened25 (BACnet Binary Input Object)		200	bOutFireDamperOpened25	3	99	contact fire damper 25 Opened				N	Y			1			
bOutFireDamperOpened26 (BACnet Binary Input Object)		200	bOutFireDamperOpened26	3	100	contact fire damper 26 Opened				N	Y			1			
bOutFireDamperOpened27 (BACnet Binary Input Object)		200	bOutFireDamperOpened27	3	101	contact fire damper 27 Opened				N	Y			1			
bOutFireDamperOpened28 (BACnet Binary Input Object)		200	bOutFireDamperOpened28	3	102	contact fire damper 28 Opened				N	Y			1			
bOutFireDamperOpened29 (BACnet Binary Input Object)		200	bOutFireDamperOpened29	3	103	contact fire damper 29 Opened				N	Y			1			
bOutFireDamperOpened30 (BACnet Binary Input Object)		200	bOutFireDamperOpened30	3	104	contact fire damper 30 Opened				N	Y			1			
bOutFireDamperOpened31 (BACnet Binary Input Object)		200	bOutFireDamperOpened31	3	105	contact fire damper 31 Opened				N	Y			1			
bOutFireDamperOpened32 (BACnet Binary Input Object)		200	bOutFireDamperOpened32	3	106	contact fire damper 32 Opened				N	Y			1			
bOutFireDamperOpened33 (BACnet Binary Input Object)		200	bOutFireDamperOpened33	3	107	contact fire damper 33 Opened				N	Y			1			

	mandatory	mandatory	mandatory	mandatory	mandatory	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional
	#keyname	device obj- instance	object-name	object- type	object- instance	description	present- value- default	min- present- value	max- present- value	settable	supports COV	hi-limit	low-limit	state-text- reference	unit-code	vendor- specific- address
fire damper	bOutFireDamperOpened34 (BACnet Binary Input Object)	200	bOutFireDamperOpened34	3	108	contact fire damper 34 Opened				N	Y			1		
	bOutFireDamperOpened35 (BACnet Binary Input Object)	200	bOutFireDamperOpened35	3	109	contact fire damper 35 Opened				N	Y			1		
	bOutFireDamperOpened36 (BACnet Binary Input Object)	200	bOutFireDamperOpened36	3	110	contact fire damper 36 Opened				N	Y			1		
	bOutFireDamperOpened37 (BACnet Binary Input Object)	200	bOutFireDamperOpened37	3	111	contact fire damper 37 Opened				N	Y			1		
	bOutFireDamperOpened38 (BACnet Binary Input Object)	200	bOutFireDamperOpened38	3	112	contact fire damper 38 Opened				N	Y			1		
	bOutFireDamperOpened39 (BACnet Binary Input Object)	200	bOutFireDamperOpened39	3	113	contact fire damper 39 Opened				N	Y			1		
	bOutFireDamperOpened40 (BACnet Binary Input Object)	200	bOutFireDamperOpened40	3	114	contact fire damper 40 Opened				N	Y			1		
	bOutFireDamperOpened41 (BACnet Binary Input Object)	200	bOutFireDamperOpened41	3	115	contact fire damper 41 Opened				N	Y			1		
	bOutFireDamperOpened42 (BACnet Binary Input Object)	200	bOutFireDamperOpened42	3	116	contact fire damper 42 Opened				N	Y			1		
	bOutFireDamperOpened43 (BACnet Binary Input Object)	200	bOutFireDamperOpened43	3	117	contact fire damper 43 Opened				N	Y			1		
	bOutFireDamperOpened44 (BACnet Binary Input Object)	200	bOutFireDamperOpened44	3	118	contact fire damper 44 Opened				N	Y			1		
	bOutFireDamperOpened45 (BACnet Binary Input Object)	200	bOutFireDamperOpened45	3	119	contact fire damper 45 Opened				N	Y			1		
	bOutFireDamperOpened46 (BACnet Binary Input Object)	200	bOutFireDamperOpened46	3	120	contact fire damper 46 Opened				N	Y			1		
	bOutFireDamperOpened47 (BACnet Binary Input Object)	200	bOutFireDamperOpened47	3	121	contact fire damper 47 Opened				N	Y			1		
	fire damper	bOutFireDamperOpened48 (BACnet Binary Input Object)	200	bOutFireDamperOpened48	3	122	contact fire damper 48 Opened				N	Y			1	
bOutFireDamperOpened49 (BACnet Binary Input Object)		200	bOutFireDamperOpened49	3	123	contact fire damper 49 Opened				N	Y			1		
bOutFireDamperOpened50 (BACnet Binary Input Object)		200	bOutFireDamperOpened50	3	124	contact fire damper 50 Opened				N	Y			1		
bOutFireDamperOpened51 (BACnet Binary Input Object)		200	bOutFireDamperOpened51	3	125	contact fire damper 51 Opened				N	Y			1		
bOutFireDamperOpened52 (BACnet Binary Input Object)		200	bOutFireDamperOpened52	3	126	contact fire damper 52 Opened				N	Y			1		
bOutFireDamperOpened53 (BACnet Binary Input Object)		200	bOutFireDamperOpened53	3	127	contact fire damper 53 Opened				N	Y			1		
bOutFireDamperOpened54 (BACnet Binary Input Object)		200	bOutFireDamperOpened54	3	128	contact fire damper 54 Opened				N	Y			1		
bOutFireDamperOpened55 (BACnet Binary Input Object)		200	bOutFireDamperOpened55	3	129	contact fire damper 55 Opened				N	Y			1		
bOutFireDamperOpened56 (BACnet Binary Input Object)		200	bOutFireDamperOpened56	3	130	contact fire damper 56 Opened				N	Y			1		
bOutFireDamperOpened57 (BACnet Binary Input Object)		200	bOutFireDamperOpened57	3	131	contact fire damper 57 Opened				N	Y			1		
bOutFireDamperOpened58 (BACnet Binary Input Object)		200	bOutFireDamperOpened58	3	132	contact fire damper 58 Opened				N	Y			1		
bOutFireDamperOpened59 (BACnet Binary Input Object)		200	bOutFireDamperOpened59	3	133	contact fire damper 59 Opened				N	Y			1		
bOutFireDamperOpened60 (BACnet Binary Input Object)		200	bOutFireDamperOpened60	3	134	contact fire damper 60 Opened				N	Y			1		
bOutFireDamperOpened61 (BACnet Binary Input Object)		200	bOutFireDamperOpened61	3	135	contact fire damper 61 Opened				N	Y			1		
bOutFireDamperOpened62 (BACnet Binary Input Object)		200	bOutFireDamperOpened62	3	136	contact fire damper 62 Opened				N	Y			1		
bOutFireDamperErrClosingRuntime1 (BACnet Binary Input Object)		200	bOutFireDamperErrClosingRuntime1	3	137	Error closing runtime fire damper 1, normally closed				N	Y			1		
bOutFireDamperErrClosingRuntime2 (BACnet Binary Input Object)		200	bOutFireDamperErrClosingRuntime2	3	138	Error closing runtime fire damper 2, normally closed				N	Y			1		
bOutFireDamperErrClosingRuntime3 (BACnet Binary Input Object)		200	bOutFireDamperErrClosingRuntime3	3	139	Error closing runtime fire damper 3, normally closed				N	Y			1		
bOutFireDamperErrClosingRuntime4 (BACnet Binary Input Object)		200	bOutFireDamperErrClosingRuntime4	3	140	Error closing runtime fire damper 4, normally closed				N	Y			1		
bOutFireDamperErrClosingRuntime5 (BACnet Binary Input Object)		200	bOutFireDamperErrClosingRuntime5	3	141	Error closing runtime fire damper 5, normally closed				N	Y			1		
bOutFireDamperErrClosingRuntime6 (BACnet Binary Input Object)		200	bOutFireDamperErrClosingRuntime6	3	142	Error closing runtime fire damper 6, normally closed				N	Y			1		

	mandatory	mandatory	mandatory	mandatory	mandatory	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional
	#keyname	device obj.-instance	object-name	object-type	object-instance	description	present-value-default	min-present-value	max-present-value	settable	supports COV	hi-limit	low-limit	state-text-reference	unit-code	vendor-specific-address
fire damper	bOutFireDamperErrClosingRuntime7 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime7	3	143	Error closing runtime fire damper 7, normally closed				N	Y			1		
	bOutFireDamperErrClosingRuntime8 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime8	3	144	Error closing runtime fire damper 8, normally closed				N	Y			1		
	bOutFireDamperErrClosingRuntime9 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime9	3	145	Error closing runtime fire damper 9, normally closed				N	Y			1		
	bOutFireDamperErrClosingRuntime10 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime10	3	146	Error closing runtime fire damper 10, normally closed				N	Y			1		
	bOutFireDamperErrClosingRuntime11 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime11	3	147	Error closing runtime fire damper 11, normally closed				N	Y			1		
	bOutFireDamperErrClosingRuntime12 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime12	3	148	Error closing runtime fire damper 12, normally closed				N	Y			1		
	bOutFireDamperErrClosingRuntime13 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime13	3	149	Error closing runtime fire damper 13, normally closed				N	Y			1		
	bOutFireDamperErrClosingRuntime14 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime14	3	150	Error closing runtime fire damper 14, normally closed				N	Y			1		
	bOutFireDamperErrClosingRuntime15 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime15	3	151	Error closing runtime fire damper 15, normally closed				N	Y			1		
	bOutFireDamperErrClosingRuntime16 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime16	3	152	Error closing runtime fire damper 16, normally closed				N	Y			1		
	bOutFireDamperErrClosingRuntime17 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime17	3	153	Error closing runtime fire damper 17, normally closed				N	Y			1		
	bOutFireDamperErrClosingRuntime18 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime18	3	154	Error closing runtime fire damper 18, normally closed				N	Y			1		
	bOutFireDamperErrClosingRuntime19 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime19	3	155	Error closing runtime fire damper 19, normally closed				N	Y			1		
	bOutFireDamperErrClosingRuntime20 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime20	3	156	Error closing runtime fire damper 20, normally closed				N	Y			1		
	fire damper	bOutFireDamperErrClosingRuntime21 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime21	3	157	Error closing runtime fire damper 21, normally closed				N	Y			1	
bOutFireDamperErrClosingRuntime22 (BACnet Binary Input Object)		200	bOutFireDamperErrClosingRuntime22	3	158	Error closing runtime fire damper 22, normally closed				N	Y			1		
bOutFireDamperErrClosingRuntime23 (BACnet Binary Input Object)		200	bOutFireDamperErrClosingRuntime23	3	159	Error closing runtime fire damper 23, normally closed				N	Y			1		
bOutFireDamperErrClosingRuntime24 (BACnet Binary Input Object)		200	bOutFireDamperErrClosingRuntime24	3	160	Error closing runtime fire damper 24, normally closed				N	Y			1		
bOutFireDamperErrClosingRuntime25 (BACnet Binary Input Object)		200	bOutFireDamperErrClosingRuntime25	3	161	Error closing runtime fire damper 25, normally closed				N	Y			1		
bOutFireDamperErrClosingRuntime26 (BACnet Binary Input Object)		200	bOutFireDamperErrClosingRuntime26	3	162	Error closing runtime fire damper 26, normally closed				N	Y			1		
bOutFireDamperErrClosingRuntime27 (BACnet Binary Input Object)		200	bOutFireDamperErrClosingRuntime27	3	163	Error closing runtime fire damper 27, normally closed				N	Y			1		
bOutFireDamperErrClosingRuntime28 (BACnet Binary Input Object)		200	bOutFireDamperErrClosingRuntime28	3	164	Error closing runtime fire damper 28, normally closed				N	Y			1		
bOutFireDamperErrClosingRuntime29 (BACnet Binary Input Object)		200	bOutFireDamperErrClosingRuntime29	3	165	Error closing runtime fire damper 29, normally closed				N	Y			1		
bOutFireDamperErrClosingRuntime30 (BACnet Binary Input Object)		200	bOutFireDamperErrClosingRuntime30	3	166	Error closing runtime fire damper 30, normally closed				N	Y			1		
bOutFireDamperErrClosingRuntime31 (BACnet Binary Input Object)		200	bOutFireDamperErrClosingRuntime31	3	167	Error closing runtime fire damper 31, normally closed				N	Y			1		
bOutFireDamperErrClosingRuntime32 (BACnet Binary Input Object)		200	bOutFireDamperErrClosingRuntime32	3	168	Error closing runtime fire damper 32, normally closed				N	Y			1		
bOutFireDamperErrClosingRuntime33 (BACnet Binary Input Object)		200	bOutFireDamperErrClosingRuntime33	3	169	Error closing runtime fire damper 33, normally closed				N	Y			1		
bOutFireDamperErrClosingRuntime34 (BACnet Binary Input Object)		200	bOutFireDamperErrClosingRuntime34	3	170	Error closing runtime fire damper 34, normally closed				N	Y			1		
fire damper		bOutFireDamperErrClosingRuntime35 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime35	3	171	Error closing runtime fire damper 35, normally closed				N	Y			1	
	bOutFireDamperErrClosingRuntime36 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime36	3	172	Error closing runtime fire damper 36, normally closed				N	Y			1		
	bOutFireDamperErrClosingRuntime37 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime37	3	173	Error closing runtime fire damper 37, normally closed				N	Y			1		
	bOutFireDamperErrClosingRuntime38 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime38	3	174	Error closing runtime fire damper 38, normally closed				N	Y			1		
	bOutFireDamperErrClosingRuntime39 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime39	3	175	Error closing runtime fire damper 39, normally closed				N	Y			1		
	bOutFireDamperErrClosingRuntime40 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime40	3	176	Error closing runtime fire damper 40, normally closed				N	Y			1		
	bOutFireDamperErrClosingRuntime41 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime41	3	177	Error closing runtime fire damper 41, normally closed				N	Y			1		

	mandatory	mandatory	mandatory	mandatory	mandatory	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional
	#keyname	device obj- instance	object-name	object- type	object- instance	description	present- value- default	min- present- value	max- present- value	settable	supports COV	hi-limit	low-limit	state-text- reference	unit-code	vendor- specific- address
fire damper	bOutFireDamperErrClosingRuntime42 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime42	3	178	Error closing runtime fire damper 42, normally closed				N	Y			1		
	bOutFireDamperErrClosingRuntime43 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime43	3	179	Error closing runtime fire damper 43, normally closed				N	Y			1		
	bOutFireDamperErrClosingRuntime44 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime44	3	180	Error closing runtime fire damper 44, normally closed				N	Y			1		
	bOutFireDamperErrClosingRuntime45 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime45	3	181	Error closing runtime fire damper 45, normally closed				N	Y			1		
	bOutFireDamperErrClosingRuntime46 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime46	3	182	Error closing runtime fire damper 46, normally closed				N	Y			1		
	bOutFireDamperErrClosingRuntime47 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime47	3	183	Error closing runtime fire damper 47, normally closed				N	Y			1		
	bOutFireDamperErrClosingRuntime48 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime48	3	184	Error closing runtime fire damper 48, normally closed				N	Y			1		
	bOutFireDamperErrClosingRuntime49 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime49	3	185	Error closing runtime fire damper 49, normally closed				N	Y			1		
	bOutFireDamperErrClosingRuntime50 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime50	3	186	Error closing runtime fire damper 50, normally closed				N	Y			1		
	bOutFireDamperErrClosingRuntime51 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime51	3	187	Error closing runtime fire damper 51, normally closed				N	Y			1		
	bOutFireDamperErrClosingRuntime52 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime52	3	188	Error closing runtime fire damper 52, normally closed				N	Y			1		
	bOutFireDamperErrClosingRuntime53 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime53	3	189	Error closing runtime fire damper 53, normally closed				N	Y			1		
	bOutFireDamperErrClosingRuntime54 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime54	3	190	Error closing runtime fire damper 54, normally closed				N	Y			1		
	bOutFireDamperErrClosingRuntime55 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime55	3	191	Error closing runtime fire damper 55, normally closed				N	Y			1		
bOutFireDamperErrClosingRuntime56 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime56	3	192	Error closing runtime fire damper 56, normally closed				N	Y			1			
bOutFireDamperErrClosingRuntime57 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime57	3	193	Error closing runtime fire damper 57, normally closed				N	Y			1			
bOutFireDamperErrClosingRuntime58 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime58	3	194	Error closing runtime fire damper 58, normally closed				N	Y			1			
bOutFireDamperErrClosingRuntime59 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime59	3	195	Error closing runtime fire damper 59, normally closed				N	Y			1			
bOutFireDamperErrClosingRuntime60 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime60	3	196	Error closing runtime fire damper 60, normally closed				N	Y			1			
bOutFireDamperErrClosingRuntime61 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime61	3	197	Error closing runtime fire damper 61, normally closed				N	Y			1			
bOutFireDamperErrClosingRuntime62 (BACnet Binary Input Object)	200	bOutFireDamperErrClosingRuntime62	3	198	Error closing runtime fire damper 62, normally closed				N	Y			1			
bOutFireDamperErrOpeningRuntime1 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime1	3	199	Error Opening runtime fire damper 1, normally closed				N	Y			1			
bOutFireDamperErrOpeningRuntime2 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime2	3	200	Error Opening runtime fire damper 2, normally closed				N	Y			1			
bOutFireDamperErrOpeningRuntime3 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime3	3	201	Error Opening runtime fire damper 3, normally closed				N	Y			1			
bOutFireDamperErrOpeningRuntime4 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime4	3	202	Error Opening runtime fire damper 4, normally closed				N	Y			1			
bOutFireDamperErrOpeningRuntime5 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime5	3	203	Error Opening runtime fire damper 5, normally closed				N	Y			1			
bOutFireDamperErrOpeningRuntime6 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime6	3	204	Error Opening runtime fire damper 6, normally closed				N	Y			1			
bOutFireDamperErrOpeningRuntime7 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime7	3	205	Error Opening runtime fire damper 7, normally closed				N	Y			1			
bOutFireDamperErrOpeningRuntime8 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime8	3	206	Error Opening runtime fire damper 8, normally closed				N	Y			1			
bOutFireDamperErrOpeningRuntime9 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime9	3	207	Error Opening runtime fire damper 9, normally closed				N	Y			1			
bOutFireDamperErrOpeningRuntime10 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime10	3	208	Error Opening runtime fire damper 10, normally closed				N	Y			1			
bOutFireDamperErrOpeningRuntime11 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime11	3	209	Error Opening runtime fire damper 11, normally closed				N	Y			1			
bOutFireDamperErrOpeningRuntime12 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime12	3	210	Error Opening runtime fire damper 12, normally closed				N	Y			1			
bOutFireDamperErrOpeningRuntime13 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime13	3	211	Error Opening runtime fire damper 13, normally closed				N	Y			1			
bOutFireDamperErrOpeningRuntime14 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime14	3	212	Error Opening runtime fire damper 14, normally closed				N	Y			1			

	mandatory	mandatory	mandatory	mandatory	mandatory	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional
	#keyname	device obj.-instance	object-name	object-type	object-instance	description	present-value-default	min-present-value	max-present-value	settable	supports COV	hi-limit	low-limit	state-text-reference	unit-code	vendor-specific-address
fire damper	bOutFireDamperErrOpeningRuntime15 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime15	3	213	Error Opening runtime fire damper 15, normally closed				N	Y			1		
	bOutFireDamperErrOpeningRuntime16 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime16	3	214	Error Opening runtime fire damper 16, normally closed				N	Y			1		
	bOutFireDamperErrOpeningRuntime17 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime17	3	215	Error Opening runtime fire damper 17, normally closed				N	Y			1		
	bOutFireDamperErrOpeningRuntime18 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime18	3	216	Error Opening runtime fire damper 18, normally closed				N	Y			1		
	bOutFireDamperErrOpeningRuntime19 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime19	3	217	Error Opening runtime fire damper 19, normally closed				N	Y			1		
	bOutFireDamperErrOpeningRuntime20 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime20	3	218	Error Opening runtime fire damper 20, normally closed				N	Y			1		
	bOutFireDamperErrOpeningRuntime21 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime21	3	219	Error Opening runtime fire damper 21, normally closed				N	Y			1		
	bOutFireDamperErrOpeningRuntime22 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime22	3	220	Error Opening runtime fire damper 22, normally closed				N	Y			1		
	bOutFireDamperErrOpeningRuntime23 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime23	3	221	Error Opening runtime fire damper 23, normally closed				N	Y			1		
	bOutFireDamperErrOpeningRuntime24 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime24	3	222	Error Opening runtime fire damper 24, normally closed				N	Y			1		
	bOutFireDamperErrOpeningRuntime25 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime25	3	223	Error Opening runtime fire damper 25, normally closed				N	Y			1		
	bOutFireDamperErrOpeningRuntime26 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime26	3	224	Error Opening runtime fire damper 26, normally closed				N	Y			1		
	bOutFireDamperErrOpeningRuntime27 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime27	3	225	Error Opening runtime fire damper 27, normally closed				N	Y			1		
	bOutFireDamperErrOpeningRuntime28 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime28	3	226	Error Opening runtime fire damper 28, normally closed				N	Y			1		
	fire damper	bOutFireDamperErrOpeningRuntime29 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime29	3	227	Error Opening runtime fire damper 29, normally closed				N	Y			1	
bOutFireDamperErrOpeningRuntime30 (BACnet Binary Input Object)		200	bOutFireDamperErrOpeningRuntime30	3	228	Error Opening runtime fire damper 30, normally closed				N	Y			1		
bOutFireDamperErrOpeningRuntime31 (BACnet Binary Input Object)		200	bOutFireDamperErrOpeningRuntime31	3	229	Error Opening runtime fire damper 31, normally closed				N	Y			1		
bOutFireDamperErrOpeningRuntime32 (BACnet Binary Input Object)		200	bOutFireDamperErrOpeningRuntime32	3	230	Error Opening runtime fire damper 32, normally closed				N	Y			1		
bOutFireDamperErrOpeningRuntime33 (BACnet Binary Input Object)		200	bOutFireDamperErrOpeningRuntime33	3	231	Error Opening runtime fire damper 33, normally closed				N	Y			1		
bOutFireDamperErrOpeningRuntime34 (BACnet Binary Input Object)		200	bOutFireDamperErrOpeningRuntime34	3	232	Error Opening runtime fire damper 34, normally closed				N	Y			1		
bOutFireDamperErrOpeningRuntime35 (BACnet Binary Input Object)		200	bOutFireDamperErrOpeningRuntime35	3	233	Error Opening runtime fire damper 35, normally closed				N	Y			1		
bOutFireDamperErrOpeningRuntime36 (BACnet Binary Input Object)		200	bOutFireDamperErrOpeningRuntime36	3	234	Error Opening runtime fire damper 36, normally closed				N	Y			1		
bOutFireDamperErrOpeningRuntime37 (BACnet Binary Input Object)		200	bOutFireDamperErrOpeningRuntime37	3	235	Error Opening runtime fire damper 37, normally closed				N	Y			1		
bOutFireDamperErrOpeningRuntime38 (BACnet Binary Input Object)		200	bOutFireDamperErrOpeningRuntime38	3	236	Error Opening runtime fire damper 38, normally closed				N	Y			1		
bOutFireDamperErrOpeningRuntime39 (BACnet Binary Input Object)		200	bOutFireDamperErrOpeningRuntime39	3	237	Error Opening runtime fire damper 39, normally closed				N	Y			1		
bOutFireDamperErrOpeningRuntime40 (BACnet Binary Input Object)		200	bOutFireDamperErrOpeningRuntime40	3	238	Error Opening runtime fire damper 40, normally closed				N	Y			1		
bOutFireDamperErrOpeningRuntime41 (BACnet Binary Input Object)		200	bOutFireDamperErrOpeningRuntime41	3	239	Error Opening runtime fire damper 41, normally closed				N	Y			1		
bOutFireDamperErrOpeningRuntime42 (BACnet Binary Input Object)		200	bOutFireDamperErrOpeningRuntime42	3	240	Error Opening runtime fire damper 42, normally closed				N	Y			1		
bOutFireDamperErrOpeningRuntime43 (BACnet Binary Input Object)		200	bOutFireDamperErrOpeningRuntime43	3	241	Error Opening runtime fire damper 43, normally closed				N	Y			1		
bOutFireDamperErrOpeningRuntime44 (BACnet Binary Input Object)		200	bOutFireDamperErrOpeningRuntime44	3	242	Error Opening runtime fire damper 44, normally closed				N	Y			1		
bOutFireDamperErrOpeningRuntime45 (BACnet Binary Input Object)		200	bOutFireDamperErrOpeningRuntime45	3	243	Error Opening runtime fire damper 45, normally closed				N	Y			1		
bOutFireDamperErrOpeningRuntime46 (BACnet Binary Input Object)		200	bOutFireDamperErrOpeningRuntime46	3	244	Error Opening runtime fire damper 46, normally closed				N	Y			1		
bOutFireDamperErrOpeningRuntime47 (BACnet Binary Input Object)		200	bOutFireDamperErrOpeningRuntime47	3	245	Error Opening runtime fire damper 47, normally closed				N	Y			1		
bOutFireDamperErrOpeningRuntime48 (BACnet Binary Input Object)		200	bOutFireDamperErrOpeningRuntime48	3	246	Error Opening runtime fire damper 48, normally closed				N	Y			1		
bOutFireDamperErrOpeningRuntime49 (BACnet Binary Input Object)		200	bOutFireDamperErrOpeningRuntime49	3	247	Error Opening runtime fire damper 49, normally closed				N	Y			1		

	mandatory	mandatory	mandatory	mandatory	mandatory	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional
	#keyname	device obj- instance	object-name	object- type	object- instance	description	present- value- default	min- present- value	max- present- value	settable	supports COV	hi-limit	low-limit	state-text- reference	unit-code	vendor- specific- address
fire damper	bOutFireDamperErrOpeningRuntime50 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime50	3	248	Error Opening runtime fire damper 50, normally closed				N	Y			1		
	bOutFireDamperErrOpeningRuntime51 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime51	3	249	Error Opening runtime fire damper 51, normally closed				N	Y			1		
	bOutFireDamperErrOpeningRuntime52 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime52	3	250	Error Opening runtime fire damper 52, normally closed				N	Y			1		
	bOutFireDamperErrOpeningRuntime53 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime53	3	251	Error Opening runtime fire damper 53, normally closed				N	Y			1		
	bOutFireDamperErrOpeningRuntime54 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime54	3	252	Error Opening runtime fire damper 54, normally closed				N	Y			1		
	bOutFireDamperErrOpeningRuntime55 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime55	3	253	Error Opening runtime fire damper 55, normally closed				N	Y			1		
	bOutFireDamperErrOpeningRuntime56 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime56	3	254	Error Opening runtime fire damper 56, normally closed				N	Y			1		
	bOutFireDamperErrOpeningRuntime57 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime57	3	255	Error Opening runtime fire damper 57, normally closed				N	Y			1		
	bOutFireDamperErrOpeningRuntime58 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime58	3	256	Error Opening runtime fire damper 58, normally closed				N	Y			1		
	bOutFireDamperErrOpeningRuntime59 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime59	3	257	Error Opening runtime fire damper 59, normally closed				N	Y			1		
	bOutFireDamperErrOpeningRuntime60 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime60	3	258	Error Opening runtime fire damper 60, normally closed				N	Y			1		
	bOutFireDamperErrOpeningRuntime61 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime61	3	259	Error Opening runtime fire damper 61, normally closed				N	Y			1		
	bOutFireDamperErrOpeningRuntime62 (BACnet Binary Input Object)	200	bOutFireDamperErrOpeningRuntime62	3	260	Error Opening runtime fire damper 62, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator1 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator1	3	261	Error end switch fire damper 1, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator2 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator2	3	262	Error end switch fire damper 2, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator3 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator3	3	263	Error end switch fire damper 3, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator4 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator4	3	264	Error end switch fire damper 4, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator5 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator5	3	265	Error end switch fire damper 5, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator6 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator6	3	266	Error end switch fire damper 6, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator7 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator7	3	267	Error end switch fire damper 7, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator8 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator8	3	268	Error end switch fire damper 8, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator9 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator9	3	269	Error end switch fire damper 9, normally closed				N	Y			1		
bOutFireDamperErrPosIndicator10 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator10	3	270	Error end switch fire damper 10, normally closed				N	Y			1			
bOutFireDamperErrPosIndicator11 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator11	3	271	Error end switch fire damper 11, normally closed				N	Y			1			
bOutFireDamperErrPosIndicator12 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator12	3	272	Error end switch fire damper 12, normally closed				N	Y			1			
bOutFireDamperErrPosIndicator13 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator13	3	273	Error end switch fire damper 13, normally closed				N	Y			1			
bOutFireDamperErrPosIndicator14 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator14	3	274	Error end switch fire damper 14, normally closed				N	Y			1			
bOutFireDamperErrPosIndicator15 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator15	3	275	Error end switch fire damper 15, normally closed				N	Y			1			
bOutFireDamperErrPosIndicator16 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator16	3	276	Error end switch fire damper 16, normally closed				N	Y			1			
bOutFireDamperErrPosIndicator17 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator17	3	277	Error end switch fire damper 17, normally closed				N	Y			1			
bOutFireDamperErrPosIndicator18 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator18	3	278	Error end switch fire damper 18, normally closed				N	Y			1			
bOutFireDamperErrPosIndicator19 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator19	3	279	Error end switch fire damper 19, normally closed				N	Y			1			
bOutFireDamperErrPosIndicator20 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator20	3	280	Error end switch fire damper 20, normally closed				N	Y			1			
bOutFireDamperErrPosIndicator21 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator21	3	281	Error end switch fire damper 21, normally closed				N	Y			1			
bOutFireDamperErrPosIndicator22 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator22	3	282	Error end switch fire damper 22, normally closed				N	Y			1			

	mandatory	mandatory	mandatory	mandatory	mandatory	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional
	#keyname	device obj- instance	object-name	object- type	object- instance	description	present- value- default	min- present- value	max- present- value	settable	supports COV	hi-limit	low-limit	state-text- reference	unit-code	vendor- specific- address
fire dam	bOutFireDamperErrPosIndicator23 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator23	3	283	Error end switch fire damper 23, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator24 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator24	3	284	Error end switch fire damper 24, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator25 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator25	3	285	Error end switch fire damper 25, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator26 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator26	3	286	Error end switch fire damper 26, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator27 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator27	3	287	Error end switch fire damper 27, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator28 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator28	3	288	Error end switch fire damper 28, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator29 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator29	3	289	Error end switch fire damper 29, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator30 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator30	3	290	Error end switch fire damper 30, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator31 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator31	3	291	Error end switch fire damper 31, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator32 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator32	3	292	Error end switch fire damper 32, normally closed				N	Y			1		
fire damper	bOutFireDamperErrPosIndicator33 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator33	3	293	Error end switch fire damper 33, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator34 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator34	3	294	Error end switch fire damper 34, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator35 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator35	3	295	Error end switch fire damper 35, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator36 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator36	3	296	Error end switch fire damper 36, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator37 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator37	3	297	Error end switch fire damper 37, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator38 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator38	3	298	Error end switch fire damper 38, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator39 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator39	3	299	Error end switch fire damper 39, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator40 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator40	3	300	Error end switch fire damper 40, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator41 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator41	3	301	Error end switch fire damper 41, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator42 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator42	3	302	Error end switch fire damper 42, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator43 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator43	3	303	Error end switch fire damper 43, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator44 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator44	3	304	Error end switch fire damper 44, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator45 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator45	3	305	Error end switch fire damper 45, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator46 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator46	3	306	Error end switch fire damper 46, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator47 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator47	3	307	Error end switch fire damper 47, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator48 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator48	3	308	Error end switch fire damper 48, normally closed				N	Y			1		
	fire damper	bOutFireDamperErrPosIndicator49 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator49	3	309	Error end switch fire damper 49, normally closed				N	Y			1	
bOutFireDamperErrPosIndicator50 (BACnet Binary Input Object)		200	bOutFireDamperErrPosIndicator50	3	310	Error end switch fire damper 50, normally closed				N	Y			1		
bOutFireDamperErrPosIndicator51 (BACnet Binary Input Object)		200	bOutFireDamperErrPosIndicator51	3	311	Error end switch fire damper 51, normally closed				N	Y			1		
bOutFireDamperErrPosIndicator52 (BACnet Binary Input Object)		200	bOutFireDamperErrPosIndicator52	3	312	Error end switch fire damper 52, normally closed				N	Y			1		
bOutFireDamperErrPosIndicator53 (BACnet Binary Input Object)		200	bOutFireDamperErrPosIndicator53	3	313	Error end switch fire damper 53, normally closed				N	Y			1		
bOutFireDamperErrPosIndicator54 (BACnet Binary Input Object)		200	bOutFireDamperErrPosIndicator54	3	314	Error end switch fire damper 54, normally closed				N	Y			1		
bOutFireDamperErrPosIndicator55 (BACnet Binary Input Object)		200	bOutFireDamperErrPosIndicator55	3	315	Error end switch fire damper 55, normally closed				N	Y			1		
bOutFireDamperErrPosIndicator56 (BACnet Binary Input Object)		200	bOutFireDamperErrPosIndicator56	3	316	Error end switch fire damper 56, normally closed				N	Y			1		
bOutFireDamperErrPosIndicator57 (BACnet Binary Input Object)		200	bOutFireDamperErrPosIndicator57	3	317	Error end switch fire damper 57, normally closed				N	Y			1		

	mandatory	mandatory	mandatory	mandatory	mandatory	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional
	#keyname	device obj.-instance	object-name	object-type	object-instance	description	present-value-default	min-present-value	max-present-value	settable	supports COV	hi-limit	low-limit	state-text-reference	unit-code	vendor-specific-address
fire damper	bOutFireDamperErrPosIndicator58 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator58	3	318	Error end switch fire damper 58, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator59 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator59	3	319	Error end switch fire damper 59, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator60 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator60	3	320	Error end switch fire damper 60, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator61 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator61	3	321	Error end switch fire damper 61, normally closed				N	Y			1		
	bOutFireDamperErrPosIndicator62 (BACnet Binary Input Object)	200	bOutFireDamperErrPosIndicator62	3	322	Error end switch fire damper 62, normally closed				N	Y			1		
	bOutFireDamperErr1 (BACnet Binary Input Object)	200	bOutFireDamperErr1	3	323	Error triggered fire damper 1, normally closed				N	Y			1		
	bOutFireDamperErr2 (BACnet Binary Input Object)	200	bOutFireDamperErr2	3	324	Error triggered fire damper 2, normally closed				N	Y			1		
	bOutFireDamperErr3 (BACnet Binary Input Object)	200	bOutFireDamperErr3	3	325	Error triggered fire damper 3, normally closed				N	Y			1		
	bOutFireDamperErr4 (BACnet Binary Input Object)	200	bOutFireDamperErr4	3	326	Error triggered fire damper 4, normally closed				N	Y			1		
	bOutFireDamperErr5 (BACnet Binary Input Object)	200	bOutFireDamperErr5	3	327	Error triggered fire damper 5, normally closed				N	Y			1		
	bOutFireDamperErr6 (BACnet Binary Input Object)	200	bOutFireDamperErr6	3	328	Error triggered fire damper 6, normally closed				N	Y			1		
	bOutFireDamperErr7 (BACnet Binary Input Object)	200	bOutFireDamperErr7	3	329	Error triggered fire damper 7, normally closed				N	Y			1		
	bOutFireDamperErr8 (BACnet Binary Input Object)	200	bOutFireDamperErr8	3	330	Error triggered fire damper 8, normally closed				N	Y			1		
	bOutFireDamperErr9 (BACnet Binary Input Object)	200	bOutFireDamperErr9	3	331	Error triggered fire damper 9, normally closed				N	Y			1		
	bOutFireDamperErr10 (BACnet Binary Input Object)	200	bOutFireDamperErr10	3	332	Error triggered fire damper 10, normally closed				N	Y			1		
	bOutFireDamperErr11 (BACnet Binary Input Object)	200	bOutFireDamperErr11	3	333	Error triggered fire damper 11, normally closed				N	Y			1		
	bOutFireDamperErr12 (BACnet Binary Input Object)	200	bOutFireDamperErr12	3	334	Error triggered fire damper 12, normally closed				N	Y			1		
	bOutFireDamperErr13 (BACnet Binary Input Object)	200	bOutFireDamperErr13	3	335	Error triggered fire damper 13, normally closed				N	Y			1		
	bOutFireDamperErr14 (BACnet Binary Input Object)	200	bOutFireDamperErr14	3	336	Error triggered fire damper 14, normally closed				N	Y			1		
	bOutFireDamperErr15 (BACnet Binary Input Object)	200	bOutFireDamperErr15	3	337	Error triggered fire damper 15, normally closed				N	Y			1		
	bOutFireDamperErr16 (BACnet Binary Input Object)	200	bOutFireDamperErr16	3	338	Error triggered fire damper 16, normally closed				N	Y			1		
	bOutFireDamperErr17 (BACnet Binary Input Object)	200	bOutFireDamperErr17	3	339	Error triggered fire damper 17, normally closed				N	Y			1		
	bOutFireDamperErr18 (BACnet Binary Input Object)	200	bOutFireDamperErr18	3	340	Error triggered fire damper 18, normally closed				N	Y			1		
	bOutFireDamperErr19 (BACnet Binary Input Object)	200	bOutFireDamperErr19	3	341	Error triggered fire damper 19, normally closed				N	Y			1		
	bOutFireDamperErr20 (BACnet Binary Input Object)	200	bOutFireDamperErr20	3	342	Error triggered fire damper 20, normally closed				N	Y			1		
	bOutFireDamperErr21 (BACnet Binary Input Object)	200	bOutFireDamperErr21	3	343	Error triggered fire damper 21, normally closed				N	Y			1		
	bOutFireDamperErr22 (BACnet Binary Input Object)	200	bOutFireDamperErr22	3	344	Error triggered fire damper 22, normally closed				N	Y			1		
	bOutFireDamperErr23 (BACnet Binary Input Object)	200	bOutFireDamperErr23	3	345	Error triggered fire damper 23, normally closed				N	Y			1		
	bOutFireDamperErr24 (BACnet Binary Input Object)	200	bOutFireDamperErr24	3	346	Error triggered fire damper 24, normally closed				N	Y			1		
	bOutFireDamperErr25 (BACnet Binary Input Object)	200	bOutFireDamperErr25	3	347	Error triggered fire damper 25, normally closed				N	Y			1		
bOutFireDamperErr26 (BACnet Binary Input Object)	200	bOutFireDamperErr26	3	348	Error triggered fire damper 26, normally closed				N	Y			1			
bOutFireDamperErr27 (BACnet Binary Input Object)	200	bOutFireDamperErr27	3	349	Error triggered fire damper 27, normally closed				N	Y			1			
bOutFireDamperErr28 (BACnet Binary Input Object)	200	bOutFireDamperErr28	3	350	Error triggered fire damper 28, normally closed				N	Y			1			
bOutFireDamperErr29 (BACnet Binary Input Object)	200	bOutFireDamperErr29	3	351	Error triggered fire damper 29, normally closed				N	Y			1			
bOutFireDamperErr30 (BACnet Binary Input Object)	200	bOutFireDamperErr30	3	352	Error triggered fire damper 30, normally closed				N	Y			1			

	mandatory	mandatory	mandatory	mandatory	mandatory	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional
	#keyname	device obj.-instance	object-name	object-type	object-instance	description	present-value-default	min-present-value	max-present-value	settable	supports COV	hi-limit	low-limit	state-text-reference	unit-code	vendor-specific-address
fire damper	bOutFireDamperErr31 (BACnet Binary Input Object)	200	bOutFireDamperErr31	3	353	Error triggered fire damper 31, normally closed				N	Y			1		
	bOutFireDamperErr32 (BACnet Binary Input Object)	200	bOutFireDamperErr32	3	354	Error triggered fire damper 32, normally closed				N	Y			1		
	bOutFireDamperErr33 (BACnet Binary Input Object)	200	bOutFireDamperErr33	3	355	Error triggered fire damper 33, normally closed				N	Y			1		
	bOutFireDamperErr34 (BACnet Binary Input Object)	200	bOutFireDamperErr34	3	356	Error triggered fire damper 34, normally closed				N	Y			1		
	bOutFireDamperErr35 (BACnet Binary Input Object)	200	bOutFireDamperErr35	3	357	Error triggered fire damper 35, normally closed				N	Y			1		
	bOutFireDamperErr36 (BACnet Binary Input Object)	200	bOutFireDamperErr36	3	358	Error triggered fire damper 36, normally closed				N	Y			1		
	bOutFireDamperErr37 (BACnet Binary Input Object)	200	bOutFireDamperErr37	3	359	Error triggered fire damper 37, normally closed				N	Y			1		
	bOutFireDamperErr38 (BACnet Binary Input Object)	200	bOutFireDamperErr38	3	360	Error triggered fire damper 38, normally closed				N	Y			1		
	bOutFireDamperErr39 (BACnet Binary Input Object)	200	bOutFireDamperErr39	3	361	Error triggered fire damper 39, normally closed				N	Y			1		
	bOutFireDamperErr40 (BACnet Binary Input Object)	200	bOutFireDamperErr40	3	362	Error triggered fire damper 40, normally closed				N	Y			1		
fire damper	bOutFireDamperErr41 (BACnet Binary Input Object)	200	bOutFireDamperErr41	3	363	Error triggered fire damper 41, normally closed				N	Y			1		
	bOutFireDamperErr42 (BACnet Binary Input Object)	200	bOutFireDamperErr42	3	364	Error triggered fire damper 42, normally closed				N	Y			1		
	bOutFireDamperErr43 (BACnet Binary Input Object)	200	bOutFireDamperErr43	3	365	Error triggered fire damper 43, normally closed				N	Y			1		
	bOutFireDamperErr44 (BACnet Binary Input Object)	200	bOutFireDamperErr44	3	366	Error triggered fire damper 44, normally closed				N	Y			1		
	bOutFireDamperErr45 (BACnet Binary Input Object)	200	bOutFireDamperErr45	3	367	Error triggered fire damper 45, normally closed				N	Y			1		
	bOutFireDamperErr46 (BACnet Binary Input Object)	200	bOutFireDamperErr46	3	368	Error triggered fire damper 46, normally closed				N	Y			1		
	bOutFireDamperErr47 (BACnet Binary Input Object)	200	bOutFireDamperErr47	3	369	Error triggered fire damper 47, normally closed				N	Y			1		
	bOutFireDamperErr48 (BACnet Binary Input Object)	200	bOutFireDamperErr48	3	370	Error triggered fire damper 48, normally closed				N	Y			1		
	bOutFireDamperErr49 (BACnet Binary Input Object)	200	bOutFireDamperErr49	3	371	Error triggered fire damper 49, normally closed				N	Y			1		
	bOutFireDamperErr50 (BACnet Binary Input Object)	200	bOutFireDamperErr50	3	372	Error triggered fire damper 50, normally closed				N	Y			1		
	bOutFireDamperErr51 (BACnet Binary Input Object)	200	bOutFireDamperErr51	3	373	Error triggered fire damper 51, normally closed				N	Y			1		
	bOutFireDamperErr52 (BACnet Binary Input Object)	200	bOutFireDamperErr52	3	374	Error triggered fire damper 52, normally closed				N	Y			1		
	bOutFireDamperErr53 (BACnet Binary Input Object)	200	bOutFireDamperErr53	3	375	Error triggered fire damper 53, normally closed				N	Y			1		
	bOutFireDamperErr54 (BACnet Binary Input Object)	200	bOutFireDamperErr54	3	376	Error triggered fire damper 54, normally closed				N	Y			1		
	bOutFireDamperErr55 (BACnet Binary Input Object)	200	bOutFireDamperErr55	3	377	Error triggered fire damper 55, normally closed				N	Y			1		
	bOutFireDamperErr56 (BACnet Binary Input Object)	200	bOutFireDamperErr56	3	378	Error triggered fire damper 56, normally closed				N	Y			1		
	bOutFireDamperErr57 (BACnet Binary Input Object)	200	bOutFireDamperErr57	3	379	Error triggered fire damper 57, normally closed				N	Y			1		
	bOutFireDamperErr58 (BACnet Binary Input Object)	200	bOutFireDamperErr58	3	380	Error triggered fire damper 58, normally closed				N	Y			1		
	bOutFireDamperErr59 (BACnet Binary Input Object)	200	bOutFireDamperErr59	3	381	Error triggered fire damper 59, normally closed				N	Y			1		
	bOutFireDamperErr60 (BACnet Binary Input Object)	200	bOutFireDamperErr60	3	382	Error triggered fire damper 60, normally closed				N	Y			1		
	bOutFireDamperErr61 (BACnet Binary Input Object)	200	bOutFireDamperErr61	3	383	Error triggered fire damper 61, normally closed				N	Y			1		
	bOutFireDamperErr62 (BACnet Binary Input Object)	200	bOutFireDamperErr62	3	384	Error triggered fire damper 62, normally closed				N	Y			1		

	mandatory	mandatory	mandatory	mandatory	mandatory	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional
	#keyname	device obj.-instance	object-name	object-type	object-instance	description	present-value-default	min-present-value	max-present-value	settable	supports COV	hi-limit	low-limit	state-text-reference	unit-code	vendor-specific-address
smoke detector	bOutSmokeDetectorErr1 (BACnet Binary Input Object)	200	bOutSmokeDetectorErr1	3	385	Error triggered smoke detector 1, normally closed				N	Y			1		
	bOutSmokeDetectorErr2 (BACnet Binary Input Object)	200	bOutSmokeDetectorErr2	3	386	Error triggered smoke detector 2, normally closed				N	Y			1		
	bOutSmokeDetectorErr3 (BACnet Binary Input Object)	200	bOutSmokeDetectorErr3	3	387	Error triggered smoke detector 3, normally closed				N	Y			1		
	bOutSmokeDetectorErr4 (BACnet Binary Input Object)	200	bOutSmokeDetectorErr4	3	388	Error triggered smoke detector 4, normally closed				N	Y			1		
	bOutSmokeDetectorErr5 (BACnet Binary Input Object)	200	bOutSmokeDetectorErr5	3	389	Error triggered smoke detector 5, normally closed				N	Y			1		
	bOutSmokeDetectorDirty1 (BACnet Binary Input Object)	200	bOutSmokeDetectorDirty1	3	390	Error triggered smoke detector 1 is dirty, normally closed				N	Y			1		
	bOutSmokeDetectorDirty2 (BACnet Binary Input Object)	200	bOutSmokeDetectorDirty2	3	391	Error triggered smoke detector 2 is dirty, normally closed				N	Y			1		
	bOutSmokeDetectorDirty3 (BACnet Binary Input Object)	200	bOutSmokeDetectorDirty3	3	392	Error triggered smoke detector 3 is dirty, normally closed				N	Y			1		
	bOutSmokeDetectorDirty4 (BACnet Binary Input Object)	200	bOutSmokeDetectorDirty4	3	393	Error triggered smoke detector 4 is dirty, normally closed				N	Y			1		
	bOutSmokeDetectorDirty5 (BACnet Binary Input Object)	200	bOutSmokeDetectorDirty5	3	394	Error triggered smoke detector 5 is dirty, normally closed				N	Y			1		
	measurement data	fOutPVTempOutdoor (BACnet Analog Input Object)	200	fOutPVTempOutdoor	0	0	present value outdoor temperature	-3,40E+38	3,40E+38		N	Y	3,40E+38	-3,40E+38		62
eOutEventNotification (BACnet Analog Input Object)		200	eOutEventNotification	0	1	0 = no error, 1 = warnings, 2 = at least one critical error	0	2		N	Y	2	0		95	
bOutVoltageError (BACnet Binary Input Object)		200	bOutVoltageError	3	395	voltage error, normally closed				N	Y			1		
bOutMainFuseError (BACnet Binary Input Object)		200	bOutMainFuseError	3	396	main fuse error, normally closed				N	Y			1		
bOutFireAlarm (BACnet Binary Input Object)		200	bOutFireAlarm	3	397	fire alarm, normally closed				N	Y			1		
bOutFrostProtection (BACnet Binary Input Object)		200	bOutFrostProtection	3	398	error frost protection, normally closed				N	Y			1		
bOutModbuslineError (BACnet Binary Input Object)		200	bOutModbuslineError	3	399	error modbus line, normally closed				N	Y			1		
fOutPVTempODA (BACnet Analog Input Object)		200	fOutPVTempODA	0	2	present value outdoor air temperature	-3,40E+38	3,40E+38		N	Y	3,40E+38	-3,40E+38		62	
fOutPVTempSUP (BACnet Analog Input Object)		200	fOutPVTempSUP	0	3	present value supply air temperature	-3,40E+38	3,40E+38		N	Y	3,40E+38	-3,40E+38		62	
fOutPVTempETA (BACnet Analog Input Object)		200	fOutPVTempETA	0	4	present value extracted air temperature	-3,40E+38	3,40E+38		N	Y	3,40E+38	-3,40E+38		62	
fOutPVTempEHA (BACnet Analog Input Object)		200	fOutPVTempEHA	0	5	present value exhausts air temperature	-3,40E+38	3,40E+38		N	Y	3,40E+38	-3,40E+38		62	
fOutPVHumODA (BACnet Analog Input Object)		200	fOutPVHumODA	0	6	present value outdoor air humidity	0	100		N	Y	100	0		29	
fOutPVHumSUP (BACnet Analog Input Object)		200	fOutPVHumSUP	0	7	present value supply air humidity	0	100		N	Y	100	0		29	
fOutPVHumETA (BACnet Analog Input Object)		200	fOutPVHumETA	0	8	present value extracted air humidity	0	100		N	Y	100	0		29	
fOutPVHumEHA (BACnet Analog Input Object)		200	fOutPVHumEHA	0	9	present value exhausts air humidity	0	100		N	Y	100	0		29	
fOutPVPressureSUP (BACnet Analog Input Object)		200	fOutPVPressureSUP	0	10	present value supply duct pressure	0	3,40E+38		N	Y	3,40E+38	0		53	
fOutPVPressureETA (BACnet Analog Input Object)		200	fOutPVPressureETA	0	11	present value exhaust duct pressure	0	3,40E+38		N	Y	3,40E+38	0		53	
fOutPV_VOC (BACnet Analog Input Object)	200	fOutPV_VOC	0	12	present value voc concentration	0	3,40E+38		N	Y	3,40E+38	0		96		
fOutPV_CO2 (BACnet Analog Input Object)	200	fOutPV_CO2	0	13	present value CO2 concentration	0	3,40E+38		N	Y	3,40E+38	0		96		
cooler	bOutCoolerMotorProtection (BACnet Binary Input Object)	200	bOutCoolerMotorProtection	3	400	error motor protection cooler pump, normally closed				N	Y			1		
	bOutCoolerValveComErr (BACnet Binary Input Object)	200	bOutCoolerValveComErr	3	401	modbus communication error with the cooler valve, normally closed				N	Y			1		
	bOutCoolerCtrlPumpON (BACnet Binary Input Object)	200	bOutCoolerCtrlPumpON	3	402	controlled value to switch on/off the cooler pump				N	Y			1		
	fOutCoolerPVValvePos (BACnet Analog Input Object)	200	fOutCoolerPVValvePos	0	14	current position of the cooler valve	0	100		N	Y	100	0		98	
	fOutCoolerCtrlValvePos (BACnet Analog Input Object)	200	fOutCoolerCtrlValvePos	0	15	controlled value of the cooler valve	0	100		N	Y	100	0		98	
	fOutCoolerPVIntletTemp (BACnet Analog Input Object)	200	fOutCoolerPVIntletTemp	0	16	present value of the cooler inlet temperature	-3,40E+38	3,40E+38		N	Y	3,40E+38	-3,40E+38		62	

	mandatory	mandatory	mandatory	mandatory	mandatory	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional
	#keyname	device obj.-instance	object-name	object-type	object-instance	description	present-value-default	min-present-value	max-present-value	settable	supports COV	hi-limit	low-limit	state-text-reference	unit-code	vendor-specific-address
preheater	bOutPreheaterMotorProtection (BACnet Binary Input Object)	200	bOutPreheaterMotorProtection	3	403	error motor protection preheater pump, normally closed				N	Y			1		
	bOutPreheaterValveComErr (BACnet Binary Input Object)	200	bOutPreheaterValveComErr	3	404	modbus communication error with the preheater valve, normally closed				N	Y			1		
	bOutPreheaterCtrlPumpON (BACnet Binary Input Object)	200	bOutPreheaterCtrlPumpON	3	405	controlled value to switch on/off the preheater pump				N	Y			1		
	fOutPreheaterPVValvePos (BACnet Analog Input Object)	200	fOutPreheaterPVValvePos	0	17	current position of the preheater valve		0	100	N	Y	100	0		98	
	fOutPreheaterCtrlValvePos (BACnet Analog Input Object)	200	fOutPreheaterCtrlValvePos	0	18	controlled value of the preheater valve		0	100	N	Y	100	0		98	
	fOutPreheaterPVReturnTemp (BACnet Analog Input Object)	200	fOutPreheaterPVReturnTemp	0	19	present value of the preheater return temperature		-3,40E+38	3,40E+38	N	Y	3,40E+38	-3,40E+38		62	
reheater	bOutReheaterMotorProtection (BACnet Binary Input Object)	200	bOutReheaterMotorProtection	3	406	error motor protection reheater pump, normally closed				N	Y			1		
	bOutReheaterValveComErr (BACnet Binary Input Object)	200	bOutReheaterValveComErr	3	407	modbus communication error with the reheater valve, normally closed				N	Y			1		
	bOutReheaterCtrlPumpON (BACnet Binary Input Object)	200	bOutReheaterCtrlPumpON	3	408	controlled value to switch on/off the reheater pump				N	Y			1		
	fOutReheaterPVValvePos (BACnet Analog Input Object)	200	fOutReheaterPVValvePos	0	20	current position of the reheater valve		0	100	N	Y	100	0		98	
	fOutReheaterCtrlValvePos (BACnet Analog Input Object)	200	fOutReheaterCtrlValvePos	0	21	controlled value of the reheater valve		0	100	N	Y	100	0		98	
	fOutReheaterPVReturnTemp (BACnet Analog Input Object)	200	fOutReheaterPVReturnTemp	0	22	present value of the reheater return temperature		-3,40E+38	3,40E+38	N	Y	3,40E+38	-3,40E+38		62	
damper	bOutDamperODAComErr (BACnet Binary Input Object)	200	bOutDamperODAComErr	3	409	modbus communication error with the outdoor air damper, normally closed				N	Y			1		
	bOutDamperSUPComErr (BACnet Binary Input Object)	200	bOutDamperSUPComErr	3	410	modbus communication error with the supply air damper, normally closed				N	Y			1		
	bOutDamperETAComErr (BACnet Binary Input Object)	200	bOutDamperETAComErr	3	411	modbus communication error with the extracted air damper, normally closed				N	Y			1		
	bOutDamperEHAComErr (BACnet Binary Input Object)	200	bOutDamperEHAComErr	3	412	modbus communication error with the exhaust air damper, normally closed				N	Y			1		
	bOutDamperFanSUPComErr (BACnet Binary Input Object)	200	bOutDamperFanSUPComErr	3	413	modbus communication error with the supply air fan damper, normally closed				N	Y			1		
	bOutDamperFanETAComErr (BACnet Binary Input Object)	200	bOutDamperFanETAComErr	3	414	modbus communication error with the extracted air fan damper, normally closed				N	Y			1		
	bOutDamperODAComErr2 (BACnet Binary Input Object)	200	bOutDamperODAComErr2	3	415	modbus communication error with the second outdoor air damper, normally closed				N	Y			1		
	bOutDamperSUPComErr2 (BACnet Binary Input Object)	200	bOutDamperSUPComErr2	3	416	modbus communication error with the second supply air damper, normally closed				N	Y			1		
	bOutDamperETAComErr2 (BACnet Binary Input Object)	200	bOutDamperETAComErr2	3	417	modbus communication error with the second extracted air damper, normally closed				N	Y			1		
	bOutDamperEHAComErr2 (BACnet Binary Input Object)	200	bOutDamperEHAComErr2	3	418	modbus communication error with the second exhaust air damper, normally closed				N	Y			1		
	bOutDamperFanSUPComErr2 (BACnet Binary Input Object)	200	bOutDamperFanSUPComErr2	3	419	modbus communication error with the second supply air fan damper, normally closed				N	Y			1		
	bOutDamperFanETAComErr2 (BACnet Binary Input Object)	200	bOutDamperFanETAComErr2	3	420	modbus communication error with the second extracted air fan damper, normally closed				N	Y			1		
damper	bOutDamperRCAComErr (BACnet Binary Input Object)	200	bOutDamperRCAComErr	3	421	modbus communication error with the recovery air damper, normally closed				N	Y			1		
	bOutDamperRCAComErr2 (BACnet Binary Input Object)	200	bOutDamperRCAComErr2	3	422	modbus communication error with the second recovery air damper, normally closed				N	Y			1		
	fOutDamperODAPVPos (BACnet Analog Input Object)	200	fOutDamperODAPVPos	0	23	current position of the outdoor air damper		0	100	N	Y	100	0		98	
	fOutDamperSUPVPos (BACnet Analog Input Object)	200	fOutDamperSUPVPos	0	24	current position of the supply air damper		0	100	N	Y	100	0		98	
	fOutDamperETAPVPos (BACnet Analog Input Object)	200	fOutDamperETAPVPos	0	25	current position of the extract air damper		0	100	N	Y	100	0		98	
	fOutDamperEHAPVPos (BACnet Analog Input Object)	200	fOutDamperEHAPVPos	0	26	current position of the exhaust air damper		0	100	N	Y	100	0		98	
	fOutDamperODAPVPos2 (BACnet Analog Input Object)	200	fOutDamperODAPVPos2	0	27	current position of the second outdoor air damper		0	100	N	Y	100	0		98	

	mandatory	mandatory	mandatory	mandatory	mandatory	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional
	#keyname	device obj.-instance	object-name	object-type	object-instance	description	present-value-default	min-present-value	max-present-value	settable	supports COV	hi-limit	low-limit	state-text-reference	unit-code	vendor-specific-address
damper	fOutDamperSUPPVPos2 (BACnet Analog Input Object)	200	fOutDamperSUPPVPos2	0	28	current position of the second supply air damper		0	100	N	Y	100	0		98	
	fOutDamperETAPVPos2 (BACnet Analog Input Object)	200	fOutDamperETAPVPos2	0	29	current position of the second extract air damper		0	100	N	Y	100	0		98	
	fOutDamperEHAPVPos2 (BACnet Analog Input Object)	200	fOutDamperEHAPVPos2	0	30	current position of the second exhaust air damper		0	100	N	Y	100	0		98	
	fOutDamperFanSUPPVPos (BACnet Analog Input Object)	200	fOutDamperFanSUPPVPos	0	31	current position of the supply air fan damper		0	100	N	Y	100	0		98	
	fOutDamperFanETAPVPos (BACnet Analog Input Object)	200	fOutDamperFanETAPVPos	0	32	current position of the extract air fan damper		0	100	N	Y	100	0		98	
	fOutDamperFanSUPPVPos2 (BACnet Analog Input Object)	200	fOutDamperFanSUPPVPos2	0	33	current position of the second supply air fan damper		0	100	N	Y	100	0		98	
	fOutDamperFanETAPVPos2 (BACnet Analog Input Object)	200	fOutDamperFanETAPVPos2	0	34	current position of the second extract air fan damper		0	100	N	Y	100	0		98	
	fOutDamperRCAPVPos (BACnet Analog Input Object)	200	fOutDamperRCAPVPos	0	35	current position of the recovery air damper		0	100	N	Y	100	0		98	
	fOutDamperRCAPVPos2 (BACnet Analog Input Object)	200	fOutDamperRCAPVPos2	0	36	current position of the second recovery air damper		0	100	N	Y	100	0		98	
	fOutDamperODACtrlPos (BACnet Analog Input Object)	200	fOutDamperODACtrlPos	0	37	controlled value of the outdoor air damper position		0	100	N	Y	100	0		98	
	fOutDamperSUPCtrlPos (BACnet Analog Input Object)	200	fOutDamperSUPCtrlPos	0	38	controlled value of the supply air damper position		0	100	N	Y	100	0		98	
	fOutDamperETACtrlPos (BACnet Analog Input Object)	200	fOutDamperETACtrlPos	0	39	controlled value of the extract air damper position		0	100	N	Y	100	0		98	
	fOutDamperEHACtrlPos (BACnet Analog Input Object)	200	fOutDamperEHACtrlPos	0	40	controlled value of the exhaust air damper position		0	100	N	Y	100	0		98	
	fOutDamperODACtrlPos2 (BACnet Analog Input Object)	200	fOutDamperODACtrlPos2	0	41	controlled value of the second outdoor air damper position		0	100	N	Y	100	0		98	
	fOutDamperSUPCtrlPos2 (BACnet Analog Input Object)	200	fOutDamperSUPCtrlPos2	0	42	controlled value of the second supply air damper position		0	100	N	Y	100	0		98	
	fOutDamperETACtrlPos2 (BACnet Analog Input Object)	200	fOutDamperETACtrlPos2	0	43	controlled value of the second extract air damper position		0	100	N	Y	100	0		98	
	fOutDamperEHACtrlPos2 (BACnet Analog Input Object)	200	fOutDamperEHACtrlPos2	0	44	controlled value of the second exhaust air damper position		0	100	N	Y	100	0		98	
	fOutDamperFanSUPCtrlPos (BACnet Analog Input Object)	200	fOutDamperFanSUPCtrlPos	0	45	controlled value of the supply air fan damper position		0	100	N	Y	100	0		98	
	fOutDamperFanETACtrlPos (BACnet Analog Input Object)	200	fOutDamperFanETACtrlPos	0	46	controlled value of the extract air fan damper position		0	100	N	Y	100	0		98	
	fOutDamperFanSUPCtrlPos2 (BACnet Analog Input Object)	200	fOutDamperFanSUPCtrlPos2	0	47	controlled value of the second supply air fan damper position		0	100	N	Y	100	0		98	
fOutDamperFanETACtrlPos2 (BACnet Analog Input Object)	200	fOutDamperFanETACtrlPos2	0	48	controlled value of the second extract air fan damper position		0	100	N	Y	100	0		98		
fOutDamperRCACtrlPos (BACnet Analog Input Object)	200	fOutDamperRCACtrlPos	0	49	controlled value of the recovery air damper position		0	100	N	Y	100	0		98		
fOutDamperRCACtrlPos2 (BACnet Analog Input Object)	200	fOutDamperRCACtrlPos2	0	50	controlled value of the second recovery air damper position		0	100	N	Y	100	0		98		
fan	bOutFanSUPMotorProtection (BACnet Binary Input Object)	200	bOutFanSUPMotorProtection	3	423	error motor protection supply air fan, normally closed				N	Y			1		
	bOutFanSUPMotorProtection2 (BACnet Binary Input Object)	200	bOutFanSUPMotorProtection2	3	424	error motor protection of the second supply air fan, normally closed				N	Y			1		
	bOutFanETAMotorProtection (BACnet Binary Input Object)	200	bOutFanETAMotorProtection	3	425	error motor protection extract air fan, normally closed				N	Y			1		
	bOutFanETAMotorProtection2 (BACnet Binary Input Object)	200	bOutFanETAMotorProtection2	3	426	error motor protection of the second extract air fan, normally closed				N	Y			1		
	bOutFanSUPRepairSwitch (BACnet Binary Input Object)	200	bOutFanSUPRepairSwitch	3	427	error repair switch supply air fan, normally closed				N	Y			1		
	bOutFanSUPRepairSwitch2 (BACnet Binary Input Object)	200	bOutFanSUPRepairSwitch2	3	428	error repair switch of the second supply air fan, normally closed				N	Y			1		
	bOutFanSUPRepairSwitch3 (BACnet Binary Input Object)	200	bOutFanSUPRepairSwitch3	3	429	error repair switch of the supply air fan 3, normally closed				N	Y			1		
	bOutFanSUPRepairSwitch4 (BACnet Binary Input Object)	200	bOutFanSUPRepairSwitch4	3	430	error repair switch of the supply air fan 4, normally closed				N	Y			1		
	bOutFanSUPRepairSwitch5 (BACnet Binary Input Object)	200	bOutFanSUPRepairSwitch5	3	431	error repair switch of the supply air fan 5, normally closed				N	Y			1		
	bOutFanSUPRepairSwitch6 (BACnet Binary Input Object)	200	bOutFanSUPRepairSwitch6	3	432	error repair switch of the supply air fan 6, normally closed				N	Y			1		
	bOutFanSUPRepairSwitch7 (BACnet Binary Input Object)	200	bOutFanSUPRepairSwitch7	3	433	error repair switch of the supply air fan 7, normally closed				N	Y			1		
	bOutFanSUPRepairSwitch8 (BACnet Binary Input Object)	200	bOutFanSUPRepairSwitch8	3	434	error repair switch of the supply air fan 8, normally closed				N	Y			1		

	mandatory	mandatory	mandatory	mandatory	mandatory	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional
	#keyname	device obj.-instance	object-name	object-type	object-instance	description	present-value-default	min-present-value	max-present-value	settable	supports COV	hi-limit	low-limit	state-text-reference	unit-code	vendor-specific-address
fan	bOutFanSUPRepairSwitch9 (BACnet Binary Input Object)	200	bOutFanSUPRepairSwitch9	3	435	error repair switch of the supply air fan 9, normally closed				N	Y			1		
	bOutFanSUPRepairSwitch10 (BACnet Binary Input Object)	200	bOutFanSUPRepairSwitch10	3	436	error repair switch of the supply air fan 10, normally closed				N	Y			1		
	bOutFanSUPRepairSwitch11 (BACnet Binary Input Object)	200	bOutFanSUPRepairSwitch11	3	437	error repair switch of the supply air fan 11, normally closed				N	Y			1		
	bOutFanSUPRepairSwitch12 (BACnet Binary Input Object)	200	bOutFanSUPRepairSwitch12	3	438	error repair switch of the supply air fan 12, normally closed				N	Y			1		
	bOutFanSUPRepairSwitch13 (BACnet Binary Input Object)	200	bOutFanSUPRepairSwitch13	3	439	error repair switch of the supply air fan 13, normally closed				N	Y			1		
	bOutFanSUPRepairSwitch14 (BACnet Binary Input Object)	200	bOutFanSUPRepairSwitch14	3	440	error repair switch of the supply air fan 14, normally closed				N	Y			1		
	bOutFanSUPRepairSwitch15 (BACnet Binary Input Object)	200	bOutFanSUPRepairSwitch15	3	441	error repair switch of the supply air fan 15, normally closed				N	Y			1		
	bOutFanSUPRepairSwitch16 (BACnet Binary Input Object)	200	bOutFanSUPRepairSwitch16	3	442	error repair switch of the supply air fan 16, normally closed				N	Y			1		
	bOutFanETARepairSwitch (BACnet Binary Input Object)	200	bOutFanETARepairSwitch	3	443	error repair switch extract air fan, normally closed				N	Y			1		
	bOutFanETARepairSwitch2 (BACnet Binary Input Object)	200	bOutFanETARepairSwitch2	3	444	error repair switch of the second extract air fan, normally closed				N	Y			1		
	bOutFanETARepairSwitch3 (BACnet Binary Input Object)	200	bOutFanETARepairSwitch3	3	445	error repair switch of the extract air fan 3, normally closed				N	Y			1		
	bOutFanETARepairSwitch4 (BACnet Binary Input Object)	200	bOutFanETARepairSwitch4	3	446	error repair switch of the extract air fan 4, normally closed				N	Y			1		
	bOutFanETARepairSwitch5 (BACnet Binary Input Object)	200	bOutFanETARepairSwitch5	3	447	error repair switch of the extract air fan 5, normally closed				N	Y			1		
	bOutFanETARepairSwitch6 (BACnet Binary Input Object)	200	bOutFanETARepairSwitch6	3	448	error repair switch of the extract air fan 6, normally closed				N	Y			1		
	bOutFanETARepairSwitch7 (BACnet Binary Input Object)	200	bOutFanETARepairSwitch7	3	449	error repair switch of the extract air fan 7, normally closed				N	Y			1		
	bOutFanETARepairSwitch8 (BACnet Binary Input Object)	200	bOutFanETARepairSwitch8	3	450	error repair switch of the extract air fan 8, normally closed				N	Y			1		
	bOutFanETARepairSwitch9 (BACnet Binary Input Object)	200	bOutFanETARepairSwitch9	3	451	error repair switch of the extract air fan 9, normally closed				N	Y			1		
	bOutFanETARepairSwitch10 (BACnet Binary Input Object)	200	bOutFanETARepairSwitch10	3	452	error repair switch of the extract air fan 10, normally closed				N	Y			1		
	bOutFanETARepairSwitch11 (BACnet Binary Input Object)	200	bOutFanETARepairSwitch11	3	453	error repair switch of the extract air fan 11, normally closed				N	Y			1		
	bOutFanETARepairSwitch12 (BACnet Binary Input Object)	200	bOutFanETARepairSwitch12	3	454	error repair switch of the extract air fan 12, normally closed				N	Y			1		
	bOutFanETARepairSwitch13 (BACnet Binary Input Object)	200	bOutFanETARepairSwitch13	3	455	error repair switch of the extract air fan 13, normally closed				N	Y			1		
	bOutFanETARepairSwitch14 (BACnet Binary Input Object)	200	bOutFanETARepairSwitch14	3	456	error repair switch of the extract air fan 14, normally closed				N	Y			1		
	bOutFanETARepairSwitch15 (BACnet Binary Input Object)	200	bOutFanETARepairSwitch15	3	457	error repair switch of the extract air fan 15, normally closed				N	Y			1		
	bOutFanETARepairSwitch16 (BACnet Binary Input Object)	200	bOutFanETARepairSwitch16	3	458	error repair switch of the extract air fan 16, normally closed				N	Y			1		
	bOutFanSUPComErr (BACnet Binary Input Object)	200	bOutFanSUPComErr	3	459	modbus communication error with the supply air fan, normally closed				N	Y			1		
	fan	bOutFanSUPComErr2 (BACnet Binary Input Object)	200	bOutFanSUPComErr2	3	460	modbus communication error with the second supply air fan, normally closed				N	Y			1	
bOutFanSUPComErr3 (BACnet Binary Input Object)		200	bOutFanSUPComErr3	3	461	modbus communication error with the supply air fan 3, normally closed				N	Y			1		
bOutFanSUPComErr4 (BACnet Binary Input Object)		200	bOutFanSUPComErr4	3	462	modbus communication error with the supply air fan 4, normally closed				N	Y			1		
bOutFanSUPComErr5 (BACnet Binary Input Object)		200	bOutFanSUPComErr5	3	463	modbus communication error with the supply air fan 5, normally closed				N	Y			1		
bOutFanSUPComErr6 (BACnet Binary Input Object)		200	bOutFanSUPComErr6	3	464	modbus communication error with the supply air fan 6, normally closed				N	Y			1		
bOutFanSUPComErr7 (BACnet Binary Input Object)		200	bOutFanSUPComErr7	3	465	modbus communication error with the supply air fan 7, normally closed				N	Y			1		
bOutFanSUPComErr8 (BACnet Binary Input Object)		200	bOutFanSUPComErr8	3	466	modbus communication error with the supply air fan 8, normally closed				N	Y			1		
bOutFanSUPComErr9 (BACnet Binary Input Object)		200	bOutFanSUPComErr9	3	467	modbus communication error with the supply air fan 9, normally closed				N	Y			1		
bOutFanSUPComErr10 (BACnet Binary Input Object)		200	bOutFanSUPComErr10	3	468	modbus communication error with the supply air fan 10, normally closed				N	Y			1		
bOutFanSUPComErr11 (BACnet Binary Input Object)		200	bOutFanSUPComErr11	3	469	modbus communication error with the supply air fan 11, normally closed				N	Y			1		

	mandatory	mandatory	mandatory	mandatory	mandatory	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional
	#keyname	device obj.-instance	object-name	object-type	object-instance	description	present-value-default	min-present-value	max-present-value	settable	supports COV	hi-limit	low-limit	state-text-reference	unit-code	vendor-specific-address
fan	bOutFanSUPComErr12 (BACnet Binary Input Object)	200	bOutFanSUPComErr12	3	470	modbus communication error with the supply air fan 12, normally closed				N	Y			1		
	bOutFanSUPComErr13 (BACnet Binary Input Object)	200	bOutFanSUPComErr13	3	471	modbus communication error with the supply air fan 13, normally closed				N	Y			1		
	bOutFanSUPComErr14 (BACnet Binary Input Object)	200	bOutFanSUPComErr14	3	472	modbus communication error with the supply air fan 14, normally closed				N	Y			1		
	bOutFanSUPComErr15 (BACnet Binary Input Object)	200	bOutFanSUPComErr15	3	473	modbus communication error with the supply air fan 15, normally closed				N	Y			1		
	bOutFanSUPComErr16 (BACnet Binary Input Object)	200	bOutFanSUPComErr16	3	474	modbus communication error with the supply air fan 16, normally closed				N	Y			1		
	bOutFanETAComErr (BACnet Binary Input Object)	200	bOutFanETAComErr	3	475	modbus communication error with the extract air fan, normally closed				N	Y			1		
	bOutFanETAComErr2 (BACnet Binary Input Object)	200	bOutFanETAComErr2	3	476	modbus communication error with the second extract air fan, normally closed				N	Y			1		
	bOutFanETAComErr3 (BACnet Binary Input Object)	200	bOutFanETAComErr3	3	477	modbus communication error with the extract air fan 3, normally closed				N	Y			1		
	bOutFanETAComErr4 (BACnet Binary Input Object)	200	bOutFanETAComErr4	3	478	modbus communication error with the extract air fan 4, normally closed				N	Y			1		
	bOutFanETAComErr5 (BACnet Binary Input Object)	200	bOutFanETAComErr5	3	479	modbus communication error with the extract air fan 5, normally closed				N	Y			1		
	bOutFanETAComErr6 (BACnet Binary Input Object)	200	bOutFanETAComErr6	3	480	modbus communication error with the extract air fan 6, normally closed				N	Y			1		
	bOutFanETAComErr7 (BACnet Binary Input Object)	200	bOutFanETAComErr7	3	481	modbus communication error with the extract air fan 7, normally closed				N	Y			1		
	bOutFanETAComErr8 (BACnet Binary Input Object)	200	bOutFanETAComErr8	3	482	modbus communication error with the extract air fan 8, normally closed				N	Y			1		
	bOutFanETAComErr9 (BACnet Binary Input Object)	200	bOutFanETAComErr9	3	483	modbus communication error with the extract air fan 9, normally closed				N	Y			1		
	bOutFanETAComErr10 (BACnet Binary Input Object)	200	bOutFanETAComErr10	3	484	modbus communication error with the extract air fan 10, normally closed				N	Y			1		
	bOutFanETAComErr11 (BACnet Binary Input Object)	200	bOutFanETAComErr11	3	485	modbus communication error with the extract air fan 11, normally closed				N	Y			1		
bOutFanETAComErr12 (BACnet Binary Input Object)	200	bOutFanETAComErr12	3	486	modbus communication error with the extract air fan 12, normally closed				N	Y			1			
bOutFanETAComErr13 (BACnet Binary Input Object)	200	bOutFanETAComErr13	3	487	modbus communication error with the extract air fan 13, normally closed				N	Y			1			
bOutFanETAComErr14 (BACnet Binary Input Object)	200	bOutFanETAComErr14	3	488	modbus communication error with the extract air fan 14, normally closed				N	Y			1			
bOutFanETAComErr15 (BACnet Binary Input Object)	200	bOutFanETAComErr15	3	489	modbus communication error with the extract air fan 15, normally closed				N	Y			1			
bOutFanETAComErr16 (BACnet Binary Input Object)	200	bOutFanETAComErr16	3	490	modbus communication error with the extract air fan 16, normally closed				N	Y			1			
fan	bOutFanSUPInErr (BACnet Binary Input Object)	200	bOutFanSUPInErr	3	491	internal supply air fan error, normally closed				N	Y			1		
	bOutFanSUPInErr2 (BACnet Binary Input Object)	200	bOutFanSUPInErr2	3	492	internal error on the second supply air fan, normally closed				N	Y			1		
	bOutFanSUPInErr3 (BACnet Binary Input Object)	200	bOutFanSUPInErr3	3	493	internal error on the supply air fan 3, normally closed				N	Y			1		
	bOutFanSUPInErr4 (BACnet Binary Input Object)	200	bOutFanSUPInErr4	3	494	internal error on the supply air fan 4, normally closed				N	Y			1		
	bOutFanSUPInErr5 (BACnet Binary Input Object)	200	bOutFanSUPInErr5	3	495	internal error on the supply air fan 5, normally closed				N	Y			1		
	bOutFanSUPInErr6 (BACnet Binary Input Object)	200	bOutFanSUPInErr6	3	496	internal error on the supply air fan 6, normally closed				N	Y			1		
	bOutFanSUPInErr7 (BACnet Binary Input Object)	200	bOutFanSUPInErr7	3	497	internal error on the supply air fan 7, normally closed				N	Y			1		
	bOutFanSUPInErr8 (BACnet Binary Input Object)	200	bOutFanSUPInErr8	3	498	internal error on the supply air fan 8, normally closed				N	Y			1		
	bOutFanSUPInErr9 (BACnet Binary Input Object)	200	bOutFanSUPInErr9	3	499	internal error on the supply air fan 9, normally closed				N	Y			1		
	bOutFanSUPInErr10 (BACnet Binary Input Object)	200	bOutFanSUPInErr10	3	500	internal error on the supply air fan 10, normally closed				N	Y			1		
	bOutFanSUPInErr11 (BACnet Binary Input Object)	200	bOutFanSUPInErr11	3	501	internal error on the supply air fan 11, normally closed				N	Y			1		
	bOutFanSUPInErr12 (BACnet Binary Input Object)	200	bOutFanSUPInErr12	3	502	internal error on the supply air fan 12, normally closed				N	Y			1		
	bOutFanSUPInErr13 (BACnet Binary Input Object)	200	bOutFanSUPInErr13	3	503	internal error on the supply air fan 13, normally closed				N	Y			1		
	bOutFanSUPInErr14 (BACnet Binary Input Object)	200	bOutFanSUPInErr14	3	504	internal error on the supply air fan 14, normally closed				N	Y			1		

	mandatory	mandatory	mandatory	mandatory	mandatory	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional
	#keyname	device obj.-instance	object-name	object-type	object-instance	description	present-value-default	min-present-value	max-present-value	settable	supports COV	hi-limit	low-limit	state-text-reference	unit-code	vendor-specific-address
fa	bOutFanSUPInErr15 (BACnet Binary Input Object)	200	bOutFanSUPInErr15	3	505	internal error on the supply air fan 15, normally closed				N	Y			1		
	bOutFanSUPInErr16 (BACnet Binary Input Object)	200	bOutFanSUPInErr16	3	506	internal error on the supply air fan 16, normally closed				N	Y			1		
	bOutFanETAInErr (BACnet Binary Input Object)	200	bOutFanETAInErr	3	507	internal extract air fan error, normally closed				N	Y			1		
	bOutFanETAInErr2 (BACnet Binary Input Object)	200	bOutFanETAInErr2	3	508	internal error on the second extract air fan, normally closed				N	Y			1		
	bOutFanETAInErr3 (BACnet Binary Input Object)	200	bOutFanETAInErr3	3	509	internal error on the extract air fan 3, normally closed				N	Y			1		
	bOutFanETAInErr4 (BACnet Binary Input Object)	200	bOutFanETAInErr4	3	510	internal error on the extract air fan 4, normally closed				N	Y			1		
	bOutFanETAInErr5 (BACnet Binary Input Object)	200	bOutFanETAInErr5	3	511	internal error on the extract air fan 5, normally closed				N	Y			1		
	bOutFanETAInErr6 (BACnet Binary Input Object)	200	bOutFanETAInErr6	3	512	internal error on the extract air fan 6, normally closed				N	Y			1		
	bOutFanETAInErr7 (BACnet Binary Input Object)	200	bOutFanETAInErr7	3	513	internal error on the extract air fan 7, normally closed				N	Y			1		
	bOutFanETAInErr8 (BACnet Binary Input Object)	200	bOutFanETAInErr8	3	514	internal error on the extract air fan 8, normally closed				N	Y			1		
	bOutFanETAInErr9 (BACnet Binary Input Object)	200	bOutFanETAInErr9	3	515	internal error on the extract air fan 9, normally closed				N	Y			1		
	bOutFanETAInErr10 (BACnet Binary Input Object)	200	bOutFanETAInErr10	3	516	internal error on the extract air fan 10, normally closed				N	Y			1		
	bOutFanETAInErr11 (BACnet Binary Input Object)	200	bOutFanETAInErr11	3	517	internal error on the extract air fan 11, normally closed				N	Y			1		
	bOutFanETAInErr12 (BACnet Binary Input Object)	200	bOutFanETAInErr12	3	518	internal error on the extract air fan 12, normally closed				N	Y			1		
	bOutFanETAInErr13 (BACnet Binary Input Object)	200	bOutFanETAInErr13	3	519	internal error on the extract air fan 13, normally closed				N	Y			1		
	fan	bOutFanETAInErr14 (BACnet Binary Input Object)	200	bOutFanETAInErr14	3	520	internal error on the extract air fan 14, normally closed				N	Y			1	
bOutFanETAInErr15 (BACnet Binary Input Object)		200	bOutFanETAInErr15	3	521	internal error on the extract air fan 15, normally closed				N	Y			1		
bOutFanETAInErr16 (BACnet Binary Input Object)		200	bOutFanETAInErr16	3	522	internal error on the extract air fan 16, normally closed				N	Y			1		
bOutFanSUPDpComErr (BACnet Binary Input Object)		200	bOutFanSUPDpComErr	3	523	modbus communication error with the pressure transmitter of the supply air fan, normally closed				N	Y			1		
bOutFanSUPDpComErr2 (BACnet Binary Input Object)		200	bOutFanSUPDpComErr2	3	524	modbus communication error with the pressure transmitter of the second supply air fan, normally closed				N	Y			1		
bOutFanETADpComErr (BACnet Binary Input Object)		200	bOutFanETADpComErr	3	525	modbus communication error with the pressure transmitter of the extract air fan, normally closed				N	Y			1		
bOutFanETADpComErr2 (BACnet Binary Input Object)		200	bOutFanETADpComErr2	3	526	modbus communication error with the pressure transmitter of the second extract air fan, normally closed				N	Y			1		
bOutFanSUPCtrlON (BACnet Binary Input Object)		200	bOutFanSUPCtrlON	3	527	controlled value to switch on/off the supply air fan				N	Y			1		
bOutFanSUPCtrlON2 (BACnet Binary Input Object)		200	bOutFanSUPCtrlON2	3	528	controlled value to switch on/off the second supply air fan				N	Y			1		
bOutFanSUPCtrlON3 (BACnet Binary Input Object)		200	bOutFanSUPCtrlON3	3	529	controlled value to switch on/off the supply air fan 3				N	Y			1		
bOutFanSUPCtrlON4 (BACnet Binary Input Object)		200	bOutFanSUPCtrlON4	3	530	controlled value to switch on/off the supply air fan 4				N	Y			1		
bOutFanSUPCtrlON5 (BACnet Binary Input Object)		200	bOutFanSUPCtrlON5	3	531	controlled value to switch on/off the supply air fan 5				N	Y			1		
bOutFanSUPCtrlON6 (BACnet Binary Input Object)		200	bOutFanSUPCtrlON6	3	532	controlled value to switch on/off the supply air fan 6				N	Y			1		
bOutFanSUPCtrlON7 (BACnet Binary Input Object)		200	bOutFanSUPCtrlON7	3	533	controlled value to switch on/off the supply air fan 7				N	Y			1		
bOutFanSUPCtrlON8 (BACnet Binary Input Object)		200	bOutFanSUPCtrlON8	3	534	controlled value to switch on/off the supply air fan 8				N	Y			1		
bOutFanSUPCtrlON9 (BACnet Binary Input Object)		200	bOutFanSUPCtrlON9	3	535	controlled value to switch on/off the supply air fan 9				N	Y			1		
bOutFanSUPCtrlON10 (BACnet Binary Input Object)	200	bOutFanSUPCtrlON10	3	536	controlled value to switch on/off the supply air fan 10				N	Y			1			
bOutFanSUPCtrlON11 (BACnet Binary Input Object)	200	bOutFanSUPCtrlON11	3	537	controlled value to switch on/off the supply air fan 11				N	Y			1			

	mandatory	mandatory	mandatory	mandatory	mandatory	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional
	#keyname	device obj.-instance	object-name	object-type	object-instance	description	present-value-default	min-present-value	max-present-value	settable	supports COV	hi-limit	low-limit	state-text-reference	unit-code	vendor-specific-address
fan	bOutFanSUPCtrlON12 (BACnet Binary Input Object)	200	bOutFanSUPCtrlON12	3	538	controlled value to switch on/off the supply air fan 12				N	Y			1		
	bOutFanSUPCtrlON13 (BACnet Binary Input Object)	200	bOutFanSUPCtrlON13	3	539	controlled value to switch on/off the supply air fan 13				N	Y			1		
	bOutFanSUPCtrlON14 (BACnet Binary Input Object)	200	bOutFanSUPCtrlON14	3	540	controlled value to switch on/off the supply air fan 14				N	Y			1		
	bOutFanSUPCtrlON15 (BACnet Binary Input Object)	200	bOutFanSUPCtrlON15	3	541	controlled value to switch on/off the supply air fan 15				N	Y			1		
	bOutFanSUPCtrlON16 (BACnet Binary Input Object)	200	bOutFanSUPCtrlON16	3	542	controlled value to switch on/off the supply air fan 16				N	Y			1		
	bOutFanETACtrlON (BACnet Binary Input Object)	200	bOutFanETACtrlON	3	543	controlled value to switch on/off the extract air fan				N	Y			1		
	bOutFanETACtrlON2 (BACnet Binary Input Object)	200	bOutFanETACtrlON2	3	544	controlled value to switch on/off the second extract air fan				N	Y			1		
	bOutFanETACtrlON3 (BACnet Binary Input Object)	200	bOutFanETACtrlON3	3	545	controlled value to switch on/off the extract air fan 3				N	Y			1		
	bOutFanETACtrlON4 (BACnet Binary Input Object)	200	bOutFanETACtrlON4	3	546	controlled value to switch on/off the extract air fan 4				N	Y			1		
	bOutFanETACtrlON5 (BACnet Binary Input Object)	200	bOutFanETACtrlON5	3	547	controlled value to switch on/off the extract air fan 5				N	Y			1		
	bOutFanETACtrlON6 (BACnet Binary Input Object)	200	bOutFanETACtrlON6	3	548	controlled value to switch on/off the extract air fan 6				N	Y			1		
	bOutFanETACtrlON7 (BACnet Binary Input Object)	200	bOutFanETACtrlON7	3	549	controlled value to switch on/off the extract air fan 7				N	Y			1		
	bOutFanETACtrlON8 (BACnet Binary Input Object)	200	bOutFanETACtrlON8	3	550	controlled value to switch on/off the extract air fan 8				N	Y			1		
	bOutFanETACtrlON9 (BACnet Binary Input Object)	200	bOutFanETACtrlON9	3	551	controlled value to switch on/off the extract air fan 9				N	Y			1		
	bOutFanETACtrlON10 (BACnet Binary Input Object)	200	bOutFanETACtrlON10	3	552	controlled value to switch on/off the extract air fan 10				N	Y			1		
	bOutFanETACtrlON11 (BACnet Binary Input Object)	200	bOutFanETACtrlON11	3	553	controlled value to switch on/off the extract air fan 11				N	Y			1		
bOutFanETACtrlON12 (BACnet Binary Input Object)	200	bOutFanETACtrlON12	3	554	controlled value to switch on/off the extract air fan 12				N	Y			1			
bOutFanETACtrlON13 (BACnet Binary Input Object)	200	bOutFanETACtrlON13	3	555	controlled value to switch on/off the extract air fan 13				N	Y			1			
bOutFanETACtrlON14 (BACnet Binary Input Object)	200	bOutFanETACtrlON14	3	556	controlled value to switch on/off the extract air fan 14				N	Y			1			
bOutFanETACtrlON15 (BACnet Binary Input Object)	200	bOutFanETACtrlON15	3	557	controlled value to switch on/off the extract air fan 15				N	Y			1			
bOutFanETACtrlON16 (BACnet Binary Input Object)	200	bOutFanETACtrlON16	3	558	controlled value to switch on/off the extract air fan 16				N	Y			1			
fan	fOutFanSUPCtrlSpeed (BACnet Analog Input Object)	200	fOutFanSUPCtrlSpeed	0	51	controlled value of the supply air fan speed		0	100	N	Y	100	0		98	
	fOutFanSUPCtrlSpeed2 (BACnet Analog Input Object)	200	fOutFanSUPCtrlSpeed2	0	52	controlled value of the second supply air fan speed		0	100	N	Y	100	0		98	
	fOutFanETACtrlSpeed (BACnet Analog Input Object)	200	fOutFanETACtrlSpeed	0	53	controlled value of the extract air fan speed		0	100	N	Y	100	0		98	
	fOutFanETACtrlSpeed2 (BACnet Analog Input Object)	200	fOutFanETACtrlSpeed2	0	54	controlled value of the second extract air fan speed		0	100	N	Y	100	0		98	
	fOutFanSUPVdp (BACnet Analog Input Object)	200	fOutFanSUPVdp	0	55	present value supply air fan differential pressure		0	3,40E+38	N	Y	3,40E+38	0		53	
	fOutFanSUPVdp2 (BACnet Analog Input Object)	200	fOutFanSUPVdp2	0	56	present value second supply air fan differential pressure		0	3,40E+38	N	Y	3,40E+38	0		53	
	fOutFanETAPVdp (BACnet Analog Input Object)	200	fOutFanETAPVdp	0	57	present value extract air fan differential pressure		0	3,40E+38	N	Y	3,40E+38	0		53	
	fOutFanETAPVdp2 (BACnet Analog Input Object)	200	fOutFanETAPVdp2	0	58	present value second extract air fan differential pressure		0	3,40E+38	N	Y	3,40E+38	0		53	
	fOutFanSUPVAirflow (BACnet Analog Input Object)	200	fOutFanSUPVAirflow	0	59	present value supply airflow		0	3,40E+38	N	Y	3,40E+38	0		135	
	fOutFanSUPVAirflow2 (BACnet Analog Input Object)	200	fOutFanSUPVAirflow2	0	60	present value supply airflow provided by the second fan		0	3,40E+38	N	Y	3,40E+38	0		135	
fOutFanETAPVAirflow (BACnet Analog Input Object)	200	fOutFanETAPVAirflow	0	61	present value extract airflow		0	3,40E+38	N	Y	3,40E+38	0		135		
fOutFanETAPVAirflow2 (BACnet Analog Input Object)	200	fOutFanETAPVAirflow2	0	62	present value extract airflow provided by the second fan		0	3,40E+38	N	Y	3,40E+38	0		135		
bOutFilterODACChangeErr (BACnet Binary Input Object)	200	bOutFilterODACChangeErr	3	559	error outdoor air filter change required, normally closed					N	Y			1		
bOutFilterSUPChangeErr (BACnet Binary Input Object)	200	bOutFilterSUPChangeErr	3	560	error supply air filter change required					N	Y			1		

	mandatory	mandatory	mandatory	mandatory	mandatory	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional
	#keyname	device obj.-instance	object-name	object-type	object-instance	description	present-value-default	min-present-value	max-present-value	settable	supports COV	hi-limit	low-limit	state-text-reference	unit-code	vendor-specific-address
filter	bOutFilterETACHangeErr (BACnet Binary Input Object)	200	bOutFilterETACHangeErr	3	561	error extract air filter change required				N	Y			1		
	bOutFilterODADpComErr (BACnet Binary Input Object)	200	bOutFilterODADpComErr	3	562	communication error pressure sensor outdoor air filter, normally closed				N	Y			1		
	bOutFilterSUPDpComErr (BACnet Binary Input Object)	200	bOutFilterSUPDpComErr	3	563	communication error pressure sensor supply air filter				N	Y			1		
	bOutFilterETADpComErr (BACnet Binary Input Object)	200	bOutFilterETADpComErr	3	564	communication error pressure sensor extract air filter				N	Y			1		
filter	tOutFilterODAHoldingTime (BACnet Analog Input Object)	200	tOutFilterODAHoldingTime	0	63	holding time outdoor air filter		0	3,40E+38	N	Y	3,40E+38	0		71	
	tOutFilterSUPHoldingTime (BACnet Analog Input Object)	200	tOutFilterSUPHoldingTime	0	64	holding time supply air filter		0	3,40E+38	N	Y	3,40E+38	0		71	
	tOutFilterETAHoldingTime (BACnet Analog Input Object)	200	tOutFilterETAHoldingTime	0	65	holding time extract air filter		0	3,40E+38	N	Y	3,40E+38	0		71	
	tOutFilterODAOperationTime (BACnet Analog Input Object)	200	tOutFilterODAOperationTime	0	66	operation time outdoor air filter		0	3,40E+38	N	Y	3,40E+38	0		71	
	tOutFilterSUPOperationTime (BACnet Analog Input Object)	200	tOutFilterSUPOperationTime	0	67	operation time supply air filter		0	3,40E+38	N	Y	3,40E+38	0		71	
	tOutFilterETAOperationTime (BACnet Analog Input Object)	200	tOutFilterETAOperationTime	0	68	operation time extract air filter		0	3,40E+38	N	Y	3,40E+38	0		71	
	fOutFilterODAPVdp (BACnet Analog Input Object)	200	fOutFilterODAPVdp	0	69	present value outdoor air filter differential pressure		0	3,40E+38	N	Y	3,40E+38	0		53	
	fOutFilterSUPPVdp (BACnet Analog Input Object)	200	fOutFilterSUPPVdp	0	70	present value supply air filter differential pressure		0	3,40E+38	N	Y	3,40E+38	0		53	
	fOutFilterETAPVdp (BACnet Analog Input Object)	200	fOutFilterETAPVdp	0	71	present value extract air filter differential pressure		0	3,40E+38	N	Y	3,40E+38	0		53	
	filter	bOutFilterODACHangeErr2 (BACnet Binary Input Object)	200	bOutFilterODACHangeErr2	3	565	error second outdoor air filter change required, normally closed				N	Y			1	
bOutFilterSUPChangeErr2 (BACnet Binary Input Object)		200	bOutFilterSUPChangeErr2	3	566	error second supply air filter change required				N	Y			1		
bOutFilterETACHangeErr2 (BACnet Binary Input Object)		200	bOutFilterETACHangeErr2	3	567	error second extract air filter change required				N	Y			1		
bOutFilterODADpComErr2 (BACnet Binary Input Object)		200	bOutFilterODADpComErr2	3	568	communication error pressure sensor second outdoor air filter, normally closed				N	Y			1		
bOutFilterSUPDpComErr2 (BACnet Binary Input Object)		200	bOutFilterSUPDpComErr2	3	569	communication error pressure sensor second supply air filter				N	Y			1		
bOutFilterETADpComErr2 (BACnet Binary Input Object)		200	bOutFilterETADpComErr2	3	570	communication error pressure sensor second extract air filter				N	Y			1		
tOutFilterODAHoldingTime2 (BACnet Analog Input Object)		200	tOutFilterODAHoldingTime2	0	72	holding time second outdoor air filter		0	3,40E+38	N	Y	3,40E+38	0		71	
tOutFilterSUPHoldingTime2 (BACnet Analog Input Object)		200	tOutFilterSUPHoldingTime2	0	73	holding time second supply air filter		0	3,40E+38	N	Y	3,40E+38	0		71	
tOutFilterETAHoldingTime2 (BACnet Analog Input Object)		200	tOutFilterETAHoldingTime2	0	74	holding time second extract air filter		0	3,40E+38	N	Y	3,40E+38	0		71	
tOutFilterODAOperationTime2 (BACnet Analog Input Object)		200	tOutFilterODAOperationTime2	0	75	operation time second outdoor air filter		0	3,40E+38	N	Y	3,40E+38	0		71	
tOutFilterSUPOperationTime2 (BACnet Analog Input Object)		200	tOutFilterSUPOperationTime2	0	76	operation time second supply air filter		0	3,40E+38	N	Y	3,40E+38	0		71	
tOutFilterETAOperationTime2 (BACnet Analog Input Object)		200	tOutFilterETAOperationTime2	0	77	operation time second extract air filter		0	3,40E+38	N	Y	3,40E+38	0		71	
fOutFilterODAPVdp2 (BACnet Analog Input Object)		200	fOutFilterODAPVdp2	0	78	present value second outdoor air filter differential pressure		0	3,40E+38	N	Y	3,40E+38	0		53	
fOutFilterSUPPVdp2 (BACnet Analog Input Object)		200	fOutFilterSUPPVdp2	0	79	present value second supply air filter differential pressure		0	3,40E+38	N	Y	3,40E+38	0		53	
fOutFilterETAPVdp2 (BACnet Analog Input Object)	200	fOutFilterETAPVdp2	0	80	present value second extract air filter differential pressure		0	3,40E+38	N	Y	3,40E+38	0		53		

	mandatory	mandatory	mandatory	mandatory	mandatory	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional
	#keyname	device obj.-instance	object-name	object-type	object-instance	description	present-value-default	min-present-value	max-present-value	settable	supports COV	hi-limit	low-limit	state-text-reference	unit-code	vendor-specific-address
heat recovery system	bOutPlateHexDamperComErr (BACnet Binary Input Object)	200	bOutPlateHexDamperComErr	3	571	modbus communication error with the plate heat exchanger damper, normally closed				N	Y			1		
	bOutPlateHexDamperComErr2 (BACnet Binary Input Object)	200	bOutPlateHexDamperComErr2	3	572	modbus communication error with the second plate heat exchanger damper, normally closed				N	Y			1		
	bOutPlateHexDpComErr (BACnet Binary Input Object)	200	bOutPlateHexDpComErr	3	573	modbus communication error with the plate heat exchanger differential pressure sensor, normally closed				N	Y			1		
	fOutPlatehexPVdp (BACnet Analog Input Object)	200	fOutPlatehexPVdp	0	81	present value plate heat exchanger differential pressure		0	3,40E+38	N	Y	3,40E+38	0		53	
	fOutPlatehexDamperCtrlPos (BACnet Analog Input Object)	200	fOutPlatehexDamperCtrlPos	0	82	controlled value bypass plate heat exchanger		0	100	N	Y	100	0		98	
	fOutPlatehexDamperCtrlPos2 (BACnet Analog Input Object)	200	fOutPlatehexDamperCtrlPos2	0	83	controlled value of the second bypass plate heat exchanger		0	100	N	Y	100	0		98	
	fOutPlatehexDamperPVPos (BACnet Analog Input Object)	200	fOutPlatehexDamperPVPos	0	84	current position bypass plate heat exchanger		0	100	N	Y	100	0		98	
	fOutPlatehexDamperPVPos2 (BACnet Analog Input Object)	200	fOutPlatehexDamperPVPos2	0	85	current position second bypass plate heat exchanger		0	100	N	Y	100	0		98	
	bOutRotHexInErr (BACnet Binary Input Object)	200	bOutRotHexInErr	3	574	internal error of the heat recovery wheel, normally closed				N	Y				1	
	bOutRotHexComErr (BACnet Binary Input Object)	200	bOutRotHexComErr	3	575	modbus communication error with the heat recovery wheel, normally closed				N	Y				1	
	bOutRotHexCtrlRel (BACnet Binary Input Object)	200	bOutRotHexCtrlRel	3	576	controlled value to release the heat recovery wheel, normally closed				N	Y				1	
	fOutRothexCtrl (BACnet Analog Input Object)	200	fOutRothexCtrl	0	86	controlled value heat recovery wheel speed		0	100	N	Y	100	0		98	
modbus communication error	bOutComErrSenHumODA (BACnet Binary Input Object)	200	bOutComErrSenHumODA	3	577	modbus communication error with the outdoor air humidity sensor, normally closed				N	Y			1		
	bOutComErrSenHumSUP (BACnet Binary Input Object)	200	bOutComErrSenHumSUP	3	578	modbus communication error with the supply air humidity sensor, normally closed				N	Y			1		
	bOutComErrSenHumETA (BACnet Binary Input Object)	200	bOutComErrSenHumETA	3	579	modbus communication error with the extract air humidity sensor, normally closed				N	Y			1		
	bOutComErrSenHumEHA (BACnet Binary Input Object)	200	bOutComErrSenHumEHA	3	580	modbus communication error with the exhaust air humidity sensor, normally closed				N	Y			1		
	bOutComErrSenTempODA (BACnet Binary Input Object)	200	bOutComErrSenTempODA	3	581	modbus communication error with the outdoor air temperature sensor, normally closed				N	Y			1		
	bOutComErrSenTempSUP (BACnet Binary Input Object)	200	bOutComErrSenTempSUP	3	582	modbus communication error with the supply air temperature sensor, normally closed				N	Y			1		
	bOutComErrSenTempETA (BACnet Binary Input Object)	200	bOutComErrSenTempETA	3	583	modbus communication error with the extract air temperature sensor, normally closed				N	Y			1		
	bOutComErrSenTempEHA (BACnet Binary Input Object)	200	bOutComErrSenTempEHA	3	584	modbus communication error with the exhaust air temperature sensor, normally closed				N	Y			1		
	bOutComErrSenDpSUP (BACnet Binary Input Object)	200	bOutComErrSenDpSUP	3	585	modbus communication error with the supply air pressure sensor, normally closed				N	Y			1		
	bOutComErrSenDpETA (BACnet Binary Input Object)	200	bOutComErrSenDpETA	3	586	modbus communication error with the extract air pressure sensor, normally closed				N	Y			1		
	bOutComErrSenCO2 (BACnet Binary Input Object)	200	bOutComErrSenCO2	3	587	modbus communication error with the CO2 sensor, normally closed				N	Y			1		
	bOutComErrSenVOC (BACnet Binary Input Object)	200	bOutComErrSenVOC	3	588	modbus communication error with the VOC sensor, normally closed				N	Y			1		
	fOutSPTempSUP (BACnet Analog Input Object)	200	fOutSPTempSUP	0	87	current set point of the supply air temperature		-3,40E+38	3,40E+38	N	Y	3,40E+38	-3,40E+38		62	
	fOutSPTempETA (BACnet Analog Input Object)	200	fOutSPTempETA	0	88	current set point of the extract or room air temperature		-3,40E+38	3,40E+38	N	Y	3,40E+38	-3,40E+38		62	

	mandatory	mandatory	mandatory	mandatory	mandatory	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional	
	#keyname	device obj- instance	object-name	object- type	object- instance	description	present- value- default	min- present- value	max- present- value	settable	supports COV	hi-limit	low-limit	state-text- reference	unit-code	vendor- specific- address	
current operation mode	current operation mode of the air handling unit.																
	eOutPVOperationMode (BACnet Analog Input Object)	200	eOutPVOperationMode	0	89	0 = off, 1 = standby, 2 = control, 3 = freeze protection, 4 = deicing, 5 = startup, 6 = shutdown, 7 = manual, 8 = nightpurge, 9 = intermittent Operation, 10 = cooling protection and 11 = fire protection			0	11	N	Y	11	0		95	
run around coil system	bOutKVS2BrinePressure1 (BACnet Binary Input Object)	200	bOutKVS2BrinePressure1	3	589	Pressure step 1 triggered 0=Off, 1=On				N	Y			1			
	bOutKVS2BrinePressure2 (BACnet Binary Input Object)	200	bOutKVS2BrinePressure2	3	590	Pressure step 2 triggered 0=Off, 1=On				N	Y			1			
	bOutKVS2MsgAutoPumpOff (BACnet Binary Input Object)	200	bOutKVS2MsgAutoPumpOff	3	591	auto pump stop PRIO=2				N	Y			1			
	bOutKVS2MsgBrinePressureCritical (BACnet Binary Input Object)	200	bOutKVS2MsgBrinePressureCritical	3	592	critical brine pressure PRIO=3				N	Y			1			
	bOutKVS2MsgBrinePressureLow (BACnet Binary Input Object)	200	bOutKVS2MsgBrinePressureLow	3	593	brine pressure have to be checked PRIO=2				N	Y			1			
	bOutKVS2MsgFrostFeedCoil (BACnet Binary Input Object)	200	bOutKVS2MsgFrostFeedCoil	3	594	alarm feed coil frosting Prio=3				N	Y			1			
	bOutKVS2MsgMinTempInletETA (BACnet Binary Input Object)	200	bOutKVS2MsgMinTempInletETA	3	595	exhaust air heat exchanger is frosting Prio=2				N	Y			1			
	bOutKVS2MsgNoFeed (BACnet Binary Input Object)	200	bOutKVS2MsgNoFeed	3	596	feed doesnt have cooling or heating effects Prio=2				N	Y			1			
	bOutKVS2MsgNoRecovery (BACnet Binary Input Object)	200	bOutKVS2MsgNoRecovery	3	597	heat recovery is currently not possible Prio=2				N	Y			1			
	bOutKVS2MsgPumpError (BACnet Binary Input Object)	200	bOutKVS2MsgPumpError	3	598	Pump error				N	Y			1			
	bOutKVS2ReleasePump (BACnet Binary Input Object)	200	bOutKVS2ReleasePump	3	599	Pump release				N	Y			1			
	bOutKVS2StateCoolingFeed (BACnet Binary Input Object)	200	bOutKVS2StateCoolingFeed	3	600	state of the cooling feed TRUE, if feeding is active				N	Y			1			
	bOutKVS2StateFastMode (BACnet Binary Input Object)	200	bOutKVS2StateFastMode	3	601	state of the fast cool- or heating mode TRUE, if active				N	Y			1			
	bOutKVS2StateHeatExchangerOperation (BACnet Binary Input Object)	200	bOutKVS2StateHeatExchangerOperation	3	602	state of the operation signal				N	Y			1			
	bOutKVS2StateHeatingFeed (BACnet Binary Input Object)	200	bOutKVS2StateHeatingFeed	3	603	state of the heating feed TRUE, if feeding is active				N	Y			1			
run around coil system	fOutKVS2CtrlFrostProtectionValve (BACnet Analog Input Object)	200	fOutKVS2CtrlFrostProtectionValve	0	90	controlled value run around coil frost protection valve		0	100	N	Y	100	0		98		
	fOutKVS2CtrlPowerValve (BACnet Analog Input Object)	200	fOutKVS2CtrlPowerValve	0	91	controlled value run around coil power valve		0	100	N	Y	100	0		98		
	fOutKVS2CtrlPump (BACnet Analog Input Object)	200	fOutKVS2CtrlPump	0	92	controlled value run around coil pump		0	100	N	Y	100	0		98		
	fOutKVS2BrineVolumeFlow (BACnet Analog Input Object)	200	fOutKVS2BrineVolumeFlow	0	93	present value brine volume flow		0	3,40E+38	N	Y	3,40E+38	0		135		
	fOutKVS2TempETAIn (BACnet Analog Input Object)	200	fOutKVS2TempETAIn	0	94	current value inlet temperature of exhaust air heat exchanger		-3,40E+38	3,40E+38	N	Y	3,40E+38	-3,40E+38		62		
	fOutKVS2TempETAOut (BACnet Analog Input Object)	200	fOutKVS2TempETAOut	0	95	current value return temperature exhaust air heat exchanger		-3,40E+38	3,40E+38	N	Y	3,40E+38	-3,40E+38		62		
	fOutKVS2TempPreFeed (BACnet Analog Input Object)	200	fOutKVS2TempPreFeed	0	96	current value brine temperature		-3,40E+38	3,40E+38	N	Y	3,40E+38	-3,40E+38		62		
	fOutKVS2TempSUPIn (BACnet Analog Input Object)	200	fOutKVS2TempSUPIn	0	97	current value inlet temperature of the fresh air heat exchanger		-3,40E+38	3,40E+38	N	Y	3,40E+38	-3,40E+38		62		
	fOutKVS2TempSUPOut (BACnet Analog Input Object)	200	fOutKVS2TempSUPOut	0	98	current value outlet temperature of the fresh air heat exchanger		-3,40E+38	3,40E+38	N	Y	3,40E+38	-3,40E+38		62		
	fOutKVS2ThermalPowerSUP (BACnet Analog Input Object)	200	fOutKVS2ThermalPowerSUP	0	99	current value thermal power of the fresh air heat exchanger		-3,40E+38	3,40E+38	N	Y	3,40E+38	-3,40E+38		48		
fOutKVS2ThermalPowerETA (BACnet Analog Input Object)	200	fOutKVS2ThermalPowerETA	0	100	current value thermal power of the exhaust air heat exchanger		-3,40E+38	3,40E+38	N	Y	3,40E+38	-3,40E+38		48			
fOutKVS2ThermalPowerFeedHeat (BACnet Analog Input Object)	200	fOutKVS2ThermalPowerFeedHeat	0	101	current value thermal power of the heating feed		-3,40E+38	3,40E+38	N	Y	3,40E+38	-3,40E+38		48			

	mandatory	mandatory	mandatory	mandatory	mandatory	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional	optional
	#keyname	device obj.-instance	object-name	object-type	object-instance	description	present-value-default	min-present-value	max-present-value	settable	supports COV	hi-limit	low-limit	state-text-reference	unit-code	vendor-specific-address
	fOutKVS2ThermalPowerFeedCool (BACnet Analog Input Object)	200	fOutKVS2ThermalPowerFeedCool	0	102	current value thermal power of the cooling feed		-3,40E+38	3,40E+38	N	Y	3,40E+38	-3,40E+38		48	
integrated refrigerating	bOutIKMsgOilManagement (BACnet Binary Input Object)	200	bOutIKMsgOilManagement	3	604	Oil management error				N	Y			1		
	bOutIKMsgLowPressure (BACnet Binary Input Object)	200	bOutIKMsgLowPressure	3	605	Low pressure error				N	Y			1		
	bOutIKMsgHighPressure (BACnet Binary Input Object)	200	bOutIKMsgHighPressure	3	606	High pressure error				N	Y			1		
	bOutIKMsgSuperHeatingController (BACnet Binary Input Object)	200	bOutIKMsgSuperHeatingController	3	607	error super heating controller				N	Y			1		
	bOutIKMsgMotorProtection1 (BACnet Binary Input Object)	200	bOutIKMsgMotorProtection1	3	608	error first compressor				N	Y			1		
	bOutIKMsgMotorProtection2 (BACnet Binary Input Object)	200	bOutIKMsgMotorProtection2	3	609	error second compressor				N	Y			1		
	bOutIKMsgMotorProtection3 (BACnet Binary Input Object)	200	bOutIKMsgMotorProtection3	3	610	error third compressor				N	Y			1		
	bOutIKCtrlPWM1 (BACnet Binary Input Object)	200	bOutIKCtrlPWM1	3	611	actuating value pwm compressor 1				N	Y			1		
	bOutIKCtrlPWM2 (BACnet Binary Input Object)	200	bOutIKCtrlPWM2	3	612	actuating value pwm compressor 2				N	Y			1		
	bOutIKCtrlPWM3 (BACnet Binary Input Object)	200	bOutIKCtrlPWM3	3	613	actuating value pwm compressor 3				N	Y			1		
	bOutIKCtrlSoftStarterOn1 (BACnet Binary Input Object)	200	bOutIKCtrlSoftStarterOn1	3	614	actuating value soft starter compressor 1				N	Y			1		
	bOutIKCtrlSoftStarterOn2 (BACnet Binary Input Object)	200	bOutIKCtrlSoftStarterOn2	3	615	actuating value soft starter compressor 2				N	Y			1		
	bOutIKCtrlSoftStarterOn3 (BACnet Binary Input Object)	200	bOutIKCtrlSoftStarterOn3	3	616	actuating value soft starter compressor 3				N	Y			1		
	bOutIKMsgHighTemp (BACnet Binary Input Object)	200	bOutIKMsgHighTemp	3	617	High compressor end temperature error				N	Y			1		
	bOutIKMsgEAPComError (BACnet Binary Input Object)	200	bOutIKMsgEAPComError	3	618	error with EAP-Communication unit				N	Y			1		